



NOTES:

- 1- If length of Conduit exceeds 10', coupling will be permitted on end adjacent to Meter.
- 2- Meter Socket & Main Breaker shall be mounted on front half on either side of home.
- 3- Minimum of 12 ft. shall be maintained between bottom of "Drip Loop" and final grade.
- 4- If height of attachment is greater than 3ft. above the roof, the mast must be guyed.
- 5- If distance from service mast to edge of roof (drop line) is less than 48", clearance may be reduced to 18 inches. Clearances shall comply with N.E.C. Article 230.



OVERHEAD SINGLE PHASE
RESIDENTIAL SERVICE
125 AMP TO 400 AMP

DATE: 01/24/2005

RESIDENTIAL
SINGLE PHASE
OVERHEAD SERVICE