

Summary of Impact Fee Study Report

by Utility Financial Solutions, LLC

Purpose of Impact Fees

Impact fees are used to fund capital-related costs (e.g., new buildings) incurred in providing governmental service to "new" development. The basic philosophy behind impact fees is that "new" development should bear the additional or "incremental" capital cost incurred and necessary to provide service to the "new" development. This establishes a cost causation or "nexus" requirement between the cost incurred in providing the service and those who benefit from the service. To be clear however, impact fees are not intended to recover annual operating expenses (e.g., utility costs) or to pay for capital expenditures related to the correction of an existing deficiency in the service provided.

The Company currently imposes an impact fee on a request for a new connection or additional service. This impact fee helps the pay a portion of the costs for the new system improvements required to serve the new development. The Company has retained Utility Financial Solutions, LLC to assist in developing an impact fee based on current conditions.

Method of Calculating Impact Fees

The UFS Report determines the allowable impact fee based on: (1) the projected additional demand for electricity from the future growth and (2) the Company's cost of constructing system improvements required to deliver this electricity to customers. The additional demand for electricity is based on the Company's projection of future growth in electricity sales caused by new customers added to the system. This projection is consistent with the recent historical growth on the HLP system. The UFS Report uses the Company's growth projections to determine the total, maximum annual demand for electricity from all classes of customers and to determine that projected increase in demand for electricity is 30,845 kW for the period 2021 through 2026.

The cost of system improvements required to serve this additional demand was provided by the Company's Impact Fee Facilities Plan. The UFS Report divides these projected costs by the projected increase in demand to determine the cost/kW of these system improvements. This amount was adjusted by a utilization factor to reflect that typical customers typically use less electric power than the size of a typical connection.

Range of Impact Fees

The UFS Report recognizes that the Company's Board may not wish to impose the fully allowable impact fee. It includes a calculation of the value brought to the system by a new customer. A comparison of impact fees from other local entities is included to demonstrate where the HLP rate will settle.

The report is as follows:

Heber Light & Power Impact Fee Study Results

Mark Beauchamp
President
Utility Financial Solutions, LLC



Utility Financial Solutions, LLC

- International consulting firm providing cost of service and financial plans and services to utilities across the country, Canada, Guam and the Caribbean
- Instructors for cost of service and financial planning for APPA, speakers for organizations across the country including AWWA.
- Hometown Connections preferred vendor for cost of service and financial analysis.



Discussion

Growth Pays for Growth

- ▶ Impacts caused by New Customers
 - Growth causes additional capacity investments
 - The investments tend to occur intermittently

- ▶ Value New Customers Provide
 - New customers generate contribution margins in the rates to fund fixed infrastructure costs
 - Cost of service study identifies the fixed and variable cost components used to identify a customer's value

Investments in System Capacity

Fund Balance		\$ 2,868,079		
Cost Component	Gross Investment	Percent of total	Allocation of Fund Balance	Net Impact
Distribution Local & Substations	\$ 10,742,000	25%	716,188	10,025,812
Distribution Substation	\$ 11,917,000	28%	794,527	11,122,473
System Substations	16,253,900	38%	1,083,676	15,170,224
Transmission System	4,105,000	10%	273,688	3,831,312
Total	\$ 43,017,900			\$ 40,149,821

	Distribution Local & Substations	System Substations	Transmission System	Total
Total Investment	\$ 21,148,284	\$ 15,170,224	\$ 3,831,312	\$ 40,149,821
Projected New Loadings	30,845	91,830	27,258	
Residential Loading Average	9.54	2.38	2.38	
Residential Equivalents	3,233	38,603	11,459	
Average Cost per RE	6,542	393	334	7,269
Contribution Value	-	-	-	2,585
Impact Average	\$ 6,542	\$ 393	\$ 334	\$ 4,684

Value from a New Customer

Customer Class	COS Revenue Requirement	Fixed Costs Contribution	Recovery Period (Years)	Utility Investment	Maximum Utility Investment per Customer
Residential	\$ 11,782,845	\$ 4,896,097	7	\$ 0.2870 per kWh	\$ 2,586
Small Commercial	2,464,627	930,437	5	41.02 per kW	2,608
Medium Commercial	2,915,961	1,143,436	5	42.59 per kW	37,338
Large Commercial	1,602,373	643,665	5	41.57 per kW	180,757

Proposed Impact Fees

	Current 120/240 Volt	Proposed 120/240 Volt	Proposed 120/208 Volt	Proposed 277/480 Volt	Dollar Adjustment	Percent Adjustment
10 A	\$ 169.25	\$ 234.19	\$ 351.54	\$ 811.24	\$ 330.72	38.4%
20 A	338.48	468.37	703.06	1,622.42	661.37	38.4%
30 A	507.73	702.57	1,054.61	2,433.66	992.09	38.4%
40 A	676.96	936.74	1,406.13	3,244.84	1,322.75	38.4%
50 A	846.21	1,170.94	1,757.67	4,056.08	1,653.46	38.4%
60 A	1,015.45	1,405.11	2,109.19	4,867.26	1,984.12	38.4%
70 A	1,184.69	1,639.31	2,460.74	5,678.49	2,314.83	38.4%
80 A	1,353.93	1,873.49	2,812.26	6,489.67	2,645.48	38.4%
90 A	1,523.18	2,107.68	3,163.80	7,300.91	2,976.20	38.4%
100 A	1,692.41	2,341.86	3,515.32	8,112.09	3,306.85	38.4%
125 A	2,115.52	2,927.33	4,394.16	10,140.13	4,133.59	38.4%
150 A	2,538.62	3,512.80	5,272.99	12,168.17	4,960.32	38.4%
175 A	2,961.73	4,098.26	6,151.83	14,196.21	5,787.05	38.4%
200 A	3,384.82	4,683.72	7,030.64	16,224.19	6,613.72	38.4%
300 A	5,077.25	7,025.59	10,545.98	24,336.34	9,920.63	38.4%
400 A	6,769.66	9,367.45	14,061.30	32,448.43	13,227.49	38.4%
500 A	8,462.07	11,709.31	17,576.62	40,560.52	16,514.34	38.4%
600 A	10,154.49	14,051.16	21,091.94	48,672.62	19,841.21	38.4%
700 A	11,846.90	16,393.02	24,607.26	56,784.71	23,148.06	38.4%
800 A	13,539.32	18,734.90	28,122.60	64,896.86	26,454.98	38.4%
900 A	15,231.73	21,076.75	31,637.92	73,008.95	29,761.83	38.4%
1000 A	16,924.15	23,418.61	35,153.24	81,121.05	33,068.70	38.4%
1100 A		25,760.47	38,668.57	89,179.25	36,321.66	38.4%
1200 A		28,102.33	42,183.88	97,286.58	39,623.75	38.4%

Proposed Impact Fees

	Proposed 120/208 Volt	Proposed 277/480 Volt	Dollar Adjustment	Percent Adjustment
1300 A	45,699.20	105,393.91	42,925.91	38.4%
1400 A	49,214.53	113,501.24	46,227.94	38.4%
1500 A	52,729.85	121,608.57	49,530.04	38.4%
1600 A	56,245.18	129,714.52	52,830.75	38.4%
1700 A	59,760.51	137,821.85	56,132.85	38.4%
1800 A	63,275.83	145,929.18	59,434.94	38.4%
1900 A	66,791.16	154,036.51	62,737.04	38.4%
2000 A	70,306.47	162,143.84	66,039.13	38.4%
2500 A	87,883.10	202,680.49	82,549.60	38.4%
3000 A	105,459.71	243,217.14	99,060.08	38.4%

Survey of Impact Charges

	Description / Panel Rating	Other Municipals & Co-ops					Average
		St. George	Santa Clara City	Hurricane City (3)	Dixie Power	Heber City (5)	
		(c)	(d)	(f)	(f)	(g)	(h)
	Residential (120/240. 1 phase)						
1	200 Amp	4,809	3,798	1,946	3,950	4,684	3,837
2	400 Amp	8,244	7,596	3,892	6,900	9,367	7,200
	Commercial (120/240. 1 phase)						
3	200 Amp	6,529	4,185	3,676	3,950	4,684	4,605
4	400 Amp	13,058	8,370	7,352	7,900	9,367	9,209
5	600 Amp	19,587	12,554	11,028	9,850	14,051	13,414
	Commercial (200Y/120V. 3 phase)						
6	200 Amp	13,068	6,282	5,518	6,666	7,031	7,713
7	400 Amp	26,136	12,563	11,036	11,850	14,061	15,129
8	600 Amp	39,204	18,845	16,555	17,775	21,092	22,694
	Commercial (480Y/277V. 3 phase)						
9	200 Amp	30,157	14,496	12,734	15,386	16,224	17,799
10	400 Amp	60,315	28,992	25,468	27,354	32,448	34,915
11	800 Amp	120,629	57,985	38,202	54,708	64,897	67,284
12	1200 Amp	180,944	86,977	76,406	82,061	97,287	104,735

Transformer Loading based on Non Coincident Peaks

*Engineer recommends that transformer not be regularly loaded above 50% of Maximum Transformer Rating for redundancy and to preserve transformer life

KVA divided by KW

Without Capital Improvents

Substation Transformer	2021			Transformer Load at 100% PF ----- Actual Power Factor	KW Rating ----- Current Loading ----- Optimal Loading*	Base Transformer Rating (kW)	Mid Transformer Rating (kW)	Max (Total) Transformer Rating (kW) ----- NCP KW ----- Optimal Load (50% of MAX)	% of Optimal* Transformer Loading	KW above(+) or Below (-) Optimal Transformer Capacity	Substation Transformer	2025			Transformer Load at 100% PF ----- Actual Power Factor	KW Rating ----- Current Loading ----- Optimal Loading*	Base Transformer Rating (kW)	Mid Transformer Rating (kW)	Max (Total) Transformer Rating (kW) ----- NCP KW ----- Optimal Load (50% of MAX)	% of Optimal* Transformer Loading	KW above(+) or Below (-) Optimal Transformer Capacity	2021 Load KW above (+) or below (-) Max Transformer Capacity	2022 Load KW above (+) or below (-) Max Transformer Capacity						
	NCP kW	%Base	%Total									NCP kW	%Base	%Total										kW	kW	kW	kW	kW	kW
Midway Transformer 10/12.5/14 MVA 46 kV – 12.47 kV	8,164	83%	58%	8330.612245 98%	KW Current Loading Optimal Loading*	10000 8164.00	12500	14000 8164	119%	1,304	Midway Transformer 10/12.5/14 MVA 46 kV – 12.47 kV	12,954	130%	93%	12,954 100%	KW Current Loading Optimal Loading*	10,000	12,500	14,000 12,954	7,000 185%	5,954	6,094	5,954						
Provo River 5 MVA (with fans) 46 kV – 12.47 kV	5,480	111%	100%	5535.353535 99%	KW Current Loading Optimal Loading*	5000.00 5480.00	5000	5480	221%	3005	Provo River (2)12/16/20 MVA 46 kV – 12.47 kV	8,034	67%	40%	8,034 100%	KW Current Loading Optimal Loading*	12,000	20,000	8,034	5221.00 10,000 80%	-1966	5,559	(1,966)						
Heber T1 12/16/20 MVA 46 kV – 12.47 kV	7,684	68%	38%	8174.468085 94%	KW Current Loading Optimal Loading*	12000 7684.00	16000	20000 7223	77%	(2,177)	Heber T1 12/16/20 MVA 46 kV – 12.47 kV	9,591	84%	48%	10,096 95%	KW Current Loading Optimal Loading*	12,000	16,000	20,000 9,591 11,363	9,500 120%	1,863	191	1,863						
Heber T2 12/16/20 MVA 46 kV – 12.47 kV	9,444	80%	47%	9480 98%	KW Current Loading Optimal Loading*	12000 9444	16000	20000 9255	94%	(545)	Heber T2 12/16/20 MVA 46 kV – 12.47 kV	16,031	134%	80%	16,031 100%	KW Current Loading Optimal Loading*	12,000	16,000	20,000 16,031 16,031	10,000 160%	6,031	6,231	6,031						
Cloyes 7.5/9.375 MVA 46 kV – 4.16 kV	6,032	86%	64%	5475 93%	KW Current Loading Optimal Loading*	7500 6032	9375	5610	129%	1,250	Cloyes 7.5/9.375 MVA 46 kV – 4.16 kV	6,032	85%	64%	6,349 95%	KW Current Loading Optimal Loading*	7,500	9,375	6,032	4,453 135%	1,579	1,673	1,579						
Jailhouse T1 10/12.5/14 MVA 46 kV – 12.47 kV	6,789	69%	48%	6900 99%	KW Current Loading Optimal Loading*	10000 6789	12500	14000 6789	98%	(141)	Jailhouse T1 10/12.5/14 MVA 46 kV – 12.47 kV	13,408	134%	96%	13,408 100%	KW Current Loading Optimal Loading*	10,000	12,500	14,000 13,408 13,408	7,000 192%	6,408	6,478	6408						
Jailhouse T2 12/16/20 MVA 46 kV – 12.47 kV	9,944	85%	50%	10200 97%	KW Current Loading Optimal Loading*	12000 9944	16000	20000 9944	103%	244	Jailhouse T2 12/16/20 MVA 46 kV – 12.47 kV	11,652	98%	58%	11,770 99%	KW Current Loading Optimal Loading*	12,000	16,000	20,000 11,652 11,652	9,900 118%	1,752	1,952	1752						
College (2) 12/16/20 MVA 46 kV – 12.47 kV	1394	12%	7%	1440 97%	KW Current Loading Optimal Loading*	12000 1394	16000	20000 1394			College (2) 12/16/120 MVA 46 kV – 12.47 kV	8073.61	69%	40%	8,238 98%	KW Current Loading Optimal Loading*	12,000	16,000	20,000 8,074 8,073	9,800 82%	(1,727)	-1,926	-1727						
East Substation (2) 12/16/120 MVA 46 kV – 12.47 kV	0	0%	0%	0 0%	KW Current Loading Optimal Loading*	12000 0	16000	20000			East Substation (2) 12/16/120 MVA 46 kV – 12.47 kV	0	0%	0%	0 0%	KW Current Loading Optimal Loading*	12,000	16,000	20,000 - -	10,000 0%	(10,000)		(10,000)						
Total City	54,931				KW	63500.00	73000.00	97375.00			Total City				89,260	KW	87,500	89,000	117,375			26,251	9,893						
Not including College		87%	56%	97%	Current Loading Optimal Loading*	54931.00	0.00	53858.84			including College & East	85,775	102%	73%	98%	Current Loading Optimal Loading*	77,741	-	84,427	29173 (above optimal at 2021 transformer cap)	NCP KW above optimal loading of existing 2021 Capacity	KW above optimal loading of 2025 Capacity	30,844						

Proposed Improvements

Proposed system improvements are summarized in the following tables. A brief description and explanation of each improvement are given. Project numbers match system maps that show proposed improvements.

Proposed System Improvements				
Proposed Improvement	Reason/Explanation	Approximate Cost	Approximate Time Frame	Added Capacity
1. Install new 2nd point of interconnection Substation.	Heber needs a second point of interconnection substation with PacifiCorp in order to keep up with load growth. The single point of interconnection that they have now is not large enough to accommodate future load growth. New substation will include a 60/80/100/112 MVA 138 kV to 46 kV transformer with room for a future transformer.	\$15,336,985	2021-2023	100 MVA
2. Install a new distribution substation located at the new 2nd point of interconnection.	<p>Provo River transformer is out of capacity according to nameplate rating during peak load when Snake Creek Hydro generation is off. Transformer fans have been added that are not reflected on the nameplate which increases the transformer capacity, but it is unknown by how much.</p> <p>During an outage of Midway transformer the Provo River transformer needs to have more capacity in order to be able to restore power to MW101 and MW102 circuits.</p> <p>It is proposed to replace the Provo River substation with a new substation located at the 2nd point of interconnection. Substation will include (2) 12/16/20 MVA transformers.</p>	\$4,964,466	2021-2023	13 MVA
3. Rebuild the 46 kV front end of Midway substation.	The 46 kV front end of Midway substation is in need of an upgrade. A new switchrack with (4) 46 kV breakers will be installed.	\$2,655,926	2024	0 MVA
4. Demolition of Provo River Substation	Provo River substation is not large enough to be able to keep up with future load growth. It is being replaced by a new substation located at the 2nd PacifiCorp interconnection. Provo River substation has reached end of life and will be demolished.	\$70,920	2023	Needed as part of project 2
5. Rebuild 46 kV line from Jailhouse tap to Jailhouse. Line should be built at 138 kV, but energized at 46 kV.	In order to accommodate a new substation in the east part of Heber the 46 kV line from Jailhouse tap to Jailhouse needs to be rebuilt. The line should be built at 138 kV, but energized at 46 kV.	\$1,248,298	2024	Needed as part of project 7

Proposed System Improvements				
Proposed Improvement	Reason/Explanation	Approximate Cost	Approximate Time Frame	Added Capacity
6. New 46 kV line from Jailhouse to new substation in the east of Heber. Line should be built at 138 kV, but energized at 46 kV.	In order to accommodate a new substation in the east part of Heber a new 46 kV line from Jailhouse to the new substation needs to be built. The line should be built at 138 kV, but energized at 46 kV.	\$2,010,606	2024	Needed as part of project 7
7. Install a new substation in the east part of Heber.	A new substation in the east part of Heber is required to be built due to load growth. The new substation should include (2) 12/16/20 MVA transformers.	\$5,771,942	2026	18 MVA
8. Install double circuit 12.47 kV underbuild on existing 46 kV transmission.	It is necessary to install double circuit 12.47 kV underbuild on existing 46 kV transmission in order to get two circuits from the new distribution substation located at the new 2nd point of interconnection over to the area currently fed by Provo River substation. The new substation will feed the Provo River circuits since Provo River substation is being taken out of service and demolished.	\$654,525	2022	Needed as part of project 2
9. Rebuild part of PR201 circuit with 477 ACSR conductor.	During an outage of the Midway transformer, upgrades to PR201 circuit are needed to be able to restore power to MW101 and MW102 circuits. This upgrade will improve capacity and help reduce voltage drop. It is proposed to upgrade PR201 from Provo River substation to approximately 600 East Main Street. Existing conductor is 4/0 ACSR and it is proposed to upgrade to 477 ACSR.	\$325,943	2022	6.4 MVA
10. Rebuild part of PR201 circuit with 477 ACSR conductor.	When Snake Creek Hydro generation is off, part of the PR201 main trunk line is overloaded during peak load. During an outage of the Midway transformer, upgrades to PR201 circuit are needed to be able to restore power to MW101 and MW102 circuits. This upgrade will improve capacity and help reduce voltage drop. It is proposed to upgrade PR201 along River Road from Main Street to 300 North and from 700 North to Burgi Lane. Existing conductor is #2 ACSR and it is proposed to upgrade to 477 ACSR.	\$444,969	2022	9.5 MVA

Proposed System Improvements				
Proposed Improvement	Reason/Explanation	Approximate Cost	Approximate Time Frame	Added Capacity
11. Rebuild part of CL402 circuit with 477 ACSR conductor.	<p>During an outage of the Midway transformer, upgrades to circuit CL402 are needed so that circuit CL402 can be used to restore power to circuit MW104.</p> <p>During an outage of the Cloyes transformer, upgrades to circuit CL402 are needed so that circuit HB303 can be used to restore power to circuit CL402.</p> <p>It is proposed to upgrade CL402 from Cloyes substation to Tate Lane Hwy 113, from 1900 South Casperville Road to 2400 South 2650 West and from 600 West 800 South to 600 West 1000 South. Existing conductor is #2 ACSR and it is proposed to upgrade to 477 ACSR.</p>	\$1,296,001	2025	9.5 MVA
12. Rebuild part of MW101 and MW102 circuits with 477 ACSR conductor.	<p>During an outage of the Provo River transformer, upgrades to circuit MW101 are needed so that circuit MW101 can be used to restore power to circuit PR201.</p> <p>It is proposed to upgrade MW101 from Midway substation to Main Street Center Street. Existing conductor is 4/0 ACSR and it is proposed to upgrade to 477 ACSR.</p> <p>It is proposed to upgrade MW101 and MW102 circuits from 220 W Main Street to 300 East Main Street. Existing conductor is 4/0 ACSR and it is proposed to upgrade to 477 ACSR.</p> <p>It is proposed to upgrade MW102 circuit from 300 W Main Street to 200 N 300 W. Existing conductor is 4/0 ACSR and it is proposed to upgrade to 477 ACSR.</p>	\$938,108	2025	6.4 MVA
13. Install a 1 MW Battery System in the Timber Lakes area.	<p>Model shows voltage issues at the end of JH502 circuit during peak load (4% drop).</p> <p>It is proposed to install a 1 MW Battery System on JH502 circuit in the Timber Lakes area. Battery will help support voltage by reducing current flow on JH502 during peak load.</p>	<p>\$1,000,000</p> <p>*No cost estimate developed. Cost was estimated by Heber City Light & Power.</p>	2022	1 MW

Proposed System Improvements				
Proposed Improvement	Reason/Explanation	Approximate Cost	Approximate Time Frame	Added Capacity
14. Rebuild part of HB305 circuit with 477 ACSR conductor.	<p>During an outage of Heber T1 transformer, upgrades to circuit HB305 are needed so that circuit HB305 can be used to restore power to circuit HB303.</p> <p>It is proposed to upgrade HB305 circuit from 600 W 200 S to 600 W 300 S. Existing conductor is #2 ACSR and it is proposed to upgrade to 477 ACSR.</p>	\$67,262	2022	9.5 MVA
15. Rebuild part of JH502 and JH503 circuits with 1100 kcmil.	<p>During an outage of Jailhouse T2 transformer, upgrades to circuits JH502 and JH503 are needed so that circuit JH503 can be used to restore power to half of circuit JH502. Power to the other half of JH502 circuit can be restored by circuit HB304.</p> <p>It is proposed to upgrade JH502 and JH503 circuits from 800 South Old Mill Drive to 2200 South Old Mill Drive Mill Drive. Existing conductor is #2 underground cable and it is proposed to upgrade to 1100 kcmil underground cable.</p>	\$528,958	2026	8.1 MVA
16. Install CO703 and CO704 circuits.	Install College substation circuits CO703 and CO704. The circuits are going to be needed to in order to support load growth. This project gets the circuits ready to use. Developers will extend the circuits as necessary as load is added to them.	\$203,514	2024	12.9 MVA
17. Install underground line on circuit CO701.	Install underground line on circuit CO701. This is new underground line is necessary to feed additional load on the CO701 circuit.	\$1,349,869	2023	12.9 MVA
	Total	\$38,868,292		

Heber Light & Power - Five Year Forecast and Capital Improvement Plan

Project Status	Added Capacity	Impact Fee Related %	Projected Cost (\$1,000)									Priority	
			Total	Impact Fee	Prior	2021	2022	2023	2024	2025	2026		
Upcoming Projects													
<i>Buildings</i>													
Partial Completion	N/A	Generator Fire Suppression System	0%	\$ 2,515	\$ -	376	291	498	684	666	-	-	M
Ongoing	N/A	New Office Building	0%	\$ 8,423	\$ -	113	300	8,010	-	-	-	-	M
Fall - 2021 Completion	N/A	EV Charging Systems	0%	\$ 130	\$ -	-	130	-	-	-	-	-	M
Partner Driven Hold	N/A	Millflat Water Line Replacement	0%	\$ 50	\$ -	-	50	-	-	-	-	-	H
Completed	N/A	Plant 2 Switchgear Room AC Unit	0%	\$ 18	\$ -	-	18	-	-	-	-	-	M
Ongoing	N/A	Gas Plant Security Measures	0%	\$ 55	\$ -	-	55	-	-	-	-	-	M
2021 Portion Complete	N/A	Plant HVAC Upgrades	0%	\$ 327	\$ -	-	85	74	84	84	-	-	H
Not Started	N/A	Plant 1 Electrical Backroom Upgrades	0%	\$ 50	\$ -	-	50	-	-	-	-	-	M
				\$ 11,568	\$ -	489	979	8,582	768	750	-	-	
<i>Generation</i>													
Ongoing	N/A	Annual Generation Capital Improvements	0%	\$ 350	\$ -	-	50	50	50	200	-	-	H
Ongoing	N/A	Lower Snake Creek Plant Upgrade	0%	\$ 35	\$ -	-	15	5	5	5	5	-	M
Ongoing	N/A	Upper Snake Creek Capital Improvements	0%	\$ 25	\$ -	-	5	5	5	5	5	-	M
Ongoing	N/A	Lake Creek Capital Improvements	0%	\$ 30	\$ -	-	5	5	5	15	5	-	M
2021 Completed	(2.3MW, 1MW)	New Generation (Battery, Engine)	0%	\$ 4,830	\$ -	-	1,000	1,315	-	1,215	1,300	-	M
Ongoing	N/A	Unit Overhauls	0%	\$ 459	\$ -	-	-	188	83	188	-	-	M
Planning	N/A	Gas Plant 1 XFMR Upgrade	0%	\$ 500	\$ -	-	-	-	-	500	-	-	L
Planning	N/A	Gas Plant 2 XFMR Upgrade	0%	\$ 500	\$ -	-	-	-	-	-	500	-	L
2022 scheduled	N/A	Gas Plant 3 Switchgear Upgrade	0%	\$ 280	\$ -	100	-	180	-	-	-	-	L
Planning	N/A	Lake Creek Bearing Replacement	0%	\$ 10	\$ -	-	-	-	-	-	10	-	L
Waiting on DAQ	N/A	Gas Plant Exhaust Compliance (WO 10813)	0%	\$ 300	\$ -	-	-	300	-	-	-	-	M
Completed	N/A	Unit 8 Jacket Heater (WO 10017)	0%	\$ 8	\$ -	-	8	-	-	-	-	-	M
August 2021 Completed	N/A	Unit 8 Generator Replacement (WO 10843)	0%	\$ 178	\$ -	-	178	-	-	-	-	-	H
Pushing to 2022	N/A	Lake Creek Breaker Replacement (WO 10016)	100%	\$ 75	\$ 75	-	75	-	-	-	-	-	M
Partner Decision Pend	N/A	Mobile Standby Generator	0%	\$ 66	\$ -	-	-	66	-	-	-	-	H
				\$ 7,646	\$ 75	100	1,336	2,114	148	2,128	1,825	-	
<i>Lines</i>													
October 2021 Complete	0 MVA	Cross Valley Transmission Line (2nd POI)	100%	\$ 6,819	\$ 6,819	2,864	3,300	655	-	-	-	-	H
Ongoing	0 MVA	Underground System Improvements	0%	\$ 756	\$ -	6	150	150	150	150	150	-	L
Ongoing	0 MVA	Aged & Environmental Distribution Replacement/Upgrade	0%	\$ 900	\$ -	150	150	150	150	150	150	-	L
Ongoing	0 MVA	Fault Indicator - Underground System	0%	\$ 50	\$ -	-	10	10	10	10	10	-	L
Planning	15.9 MVA	Rebuild PR201_Main Street to Burgi Lane	100%	\$ 771	\$ 771	-	-	771	-	-	-	-	H
Partial / Planning	25 MVA	Additional Circuits out of Jailhouse to the East	100%	\$ 560	\$ 560	280	-	140	140	-	-	-	H
Planning	25.8 MVA	Additional Circuits out of College to South and East	100%	\$ 1,554	\$ 1,554	-	-	-	1,350	204	-	-	H
Planning	0 MVA	Install Voltage Regulators at Timber Lakes Gate	100%	\$ 100	\$ 100	-	-	100	-	-	-	-	M
Planning	25 MVA	Heber Substation Additional Circuits (South & West)	100%	\$ 280	\$ 280	-	-	280	-	-	-	-	M
Planning	9.5 MVA	Reconductor HB305_600 West - Substation to 300 South	100%	\$ 67	\$ 67	-	-	67	-	-	-	-	H
Planning	0 MVA	Midway Substation - Get Aways	50%	\$ 160	\$ 80	-	-	-	160	-	-	-	H
Planning	5 MVA	Load to Parsons (Reconductor)	0%	\$ 100	\$ -	-	-	-	100	-	-	-	L
Planning	9.5 MVA	Reconductor Heber City Main 600 S to 1000 S	100%	\$ 100	\$ 100	-	-	-	100	-	-	-	L
Planning	0 MVA	Jailhouse Tap Transmission Line and East Extension	100%	\$ 3,259	\$ 3,259	-	-	-	-	3,259	-	-	L
Planning	8 MVA	Reconductor Pine Canyon Road - Midway	60%	\$ 180	\$ 108	-	-	-	-	180	-	-	H
Planning	8.1 MVA	Reconductor JH502/503_Old Mill Drive - 800 South to 1200 South	100%	\$ -	\$ -	-	-	-	-	-	-	529	L
Planning	6.4 MVA	Reconductor MW101/102 from 4/O to 477	100%	\$ 938	\$ 938	-	-	-	-	-	938	-	L
Planning	9.5 MVA	Rebuild CL402_600 West to Tate Lane	100%	\$ 1,296	\$ 1,296	-	-	-	-	-	1,296	-	L
Completed	0 MVA	Holmes Homes Subdivision Asset Purchase	100%	\$ 150	\$ 150	-	150	-	-	-	-	-	H
Design/Contractor Queue	9.5 MVA	New Circuit to Hwy 32	100%	\$ 720	\$ 720	-	720	-	-	-	-	-	H
Planning	5 MVA	Tie line from 305 to 402 to 303	100%	\$ -	\$ -	-	-	-	-	-	-	-	M
Customer Driven	5 MVA	Tie from 702 up to 500 East in Heber (HB304)	100%	\$ -	\$ -	-	-	-	-	-	-	-	H
				\$ 18,760	\$ 16,802	3,300	4,480	2,323	2,160	3,953	2,544	529	
<i>Substation</i>													
Design - Summer 2022	100 MVA	2nd Point of Interconnect Substation	70%	\$ 15,337	\$ 3,000	2,432	2,605	10,300	-	-	-	-	H
Ongoing	0	Replacement Recloser for Joslyn Reclosers	0%	\$ 100	\$ -	75	25	-	-	-	-	-	L
Ongoing	0	Substation Bird Guard	0%	\$ 15	\$ -	6	6	3	-	-	-	-	H
Planning	18 MVA	East Substation	100%	\$ 750	\$ 750	-	750	-	-	-	-	5,772	M
Planning	0	Cloyes LTC Rebuild	0%	\$ 40	\$ -	-	-	-	40	-	-	-	M
Design - Summer 2022	13 MVA	Provo River Substation Rebuild	100%	\$ 5,035	\$ 5,035	-	-	4,964	71	-	-	-	M
CY2022	0	Battery Replacement Program	0%	\$ 29	\$ -	-	-	10	-	19	8	-	L
Planning	0	Midway Substation - High Side Rebuild	90%	\$ 2,656	\$ 2,390	-	-	-	-	2,656	-	-	L
Planning	0	Heber Relay Upgrade	0%	\$ 25	\$ -	-	-	-	-	25	-	-	L
Planning	0	Jailhouse Lease Buyout or Extension	0%	\$ 100	\$ -	-	-	100	-	-	-	-	L
Planning	0	Jailhouse Fence Replacement	0%	\$ 129	\$ -	-	-	-	-	-	129	-	M
				\$ 24,216	\$ 11,175	2,513	3,386	15,377	71	2,740	137	5,772	
<i>Systems & Technology</i>													
Ongoing	N/A	Annual IT Upgrades	0%	\$ 309	\$ -	-	124	50	85	50	44	-	M
Ongoing	N/A	Annual OT Upgrades	0%	\$ 408	\$ -	-	318	30	30	30	30	-	M
Ongoing	N/A	Fiber Improvements	0%	\$ 110	\$ -	-	50	20	20	20	20	-	M
Ongoing	N/A	Smart Grid Investment	0%	\$ 50	\$ -	-	10	10	10	10	10	-	M
Ongoing	N/A	AMI Tower - North Village	0%	\$ 70	\$ -	-	-	70	-	-	-	-	M
				\$ 947	\$ -	-	502	180	145	110	104	-	
<i>Tools & Equipment</i>													
Ongoing	N/A	Annual Tool & Equipment Purchases	0%	\$ 235	\$ -	-	55	45	45	45	45	45	M
<i>Vehicle</i>													
Ongoing	N/A	Annual Vehicle Program	0%	\$ 2,360	\$ -	-	435	300	170	635	820	500	M
				\$ 65,732	\$ 28,052	6,402	11,173	28,921	3,507	10,361	5,475	6,846	

2027 - 2031 Forecasted Projects

<i>Buildings</i>		Generator Plant 4	
<i>Generation</i>		Unit Overhauls (Multiple Years)	280
<i>Lines</i>		Lake Creek to Timberlakes Rebuild/Reconductor	350
		3-Phase Extension up Lake Creek Road from Timberlakes Gate	500
		East Substation Circuit Extension	400-900
		Cabin Developments Overhead to Underground Conversion	?
<i>Substation</i>		Battery Replacement Program (Multiple Years)	\$8/Year
		Cloyes XFMR Upgrade (2028)	500
		Sorenson Substation (2029)	6,000
		Gas Plant 2 XFMR Upgrade (2028)	500
<i>Systems & Technology</i>		Server Upgrade (2027)	63