

Fiscal Year 2022 Fees/Rates, Operating and Capital Budgets

Approved: 12/15/2021



2022 Rates/Fees

Fees

| Description | Amount | Comments |
|---|-------------------|--|
| Billing/Office Fees | | |
| Convenience Fee | 3% | Used on Impact Fee and Work Order credit card payments only |
| Late Payment Charge (Compounded) | 1.5% | Applied on any past due amounts |
| Returned Payment Charge | 15.00 | |
| Reconnect Fee | 20.00 | |
| Service Application Fee | 20.00 | |
| Seasonal Disconnect Fee | 50.00 | |
| Construction Fees | | |
| Impact Fee | Amperage Calc | Included in current schedule |
| Line Extension/New Development - Installation | Bid Estimate | Estimate for Labor, Materials, and Overhead provided upon request |
| Initiation/Will Serve | 200.00 | Check only |
| Design Fee | 300.00 | This is a per development phase fee |
| Design Fee (resubmit) | 20.00 | Per residential/commercial unit |
| Truck Roll Fee | 50.00 | Set fee for extra vehicle trips, i.e. reinspection, meter verification, troubleshooting customer side, etc |
| Temporary Meter Connection | 500.00 | Fee for new services that desire a temporary meter set |
| New Service / Meter Related Fees | | |
| Wire Pull (up to 400 amps) | 300.00 plus meter | Customer responsible for wire on services larger than 400 amps. |
| Meter Installation Fee – Single Phase | 235.00 | All new meter issuances regardless of reason, does not |
| Meter Installation Fee – 3-Phase | 470.00 | include replacement meters. |
| Meter - Nonstandard Meter - Monthly Meter Reading Charge | 20.00 | Typically those meters that must be manually read |
| Net Metering - Application Fee | 300.00 | Included in current schedule. |
| Device Fees | | |
| Generation Transfer Switch - Preliminary Inspection Fee | 100.00 | Verification trip for sizing and device appropriateness |
| Generation Transfer Switch - Installation Fee | 100.00 | Installation and meter re-installation |
| Outside Lighting (Yard Lights) | \$6.50/Month | Set fee regardless of consumption levels |
| Outside Lighting Maintenance | 25.00 plus parts | |

Approved: 12/15/2021 Page 1 of 75

Rates

| Residential | |
|--|-----------------------|
| Base/Customer Charge | 14.90 |
| 1st 1,000 kWh | 0.0893/kWh |
| All Additional | 0.1097/kWh |
| Residential/Small Commercial - Pumping | |
| Base/Customer Charge | 17.00 |
| Demand Rate | $9.85/\mathrm{kW}$ |
| All kWh | 0.063/kWh |
| General Service - Small (1kW <x<= (single="" 30kw)="" phase)<="" td=""><td></td></x<=> | |
| Base/Customer Charge | 14.00 |
| Demand Rate | 10.10/kW |
| 1st 500 kWh | 0.081/kWh |
| All Additional | 0.051/kWh |
| General Service - Small (1kW <x<= (3-phase)<="" 30kw)="" td=""><td></td></x<=> | |
| Base/Customer Charge | 19.00 |
| Demand Rate | 10.10/kW |
| 1st 500 kWh | 0.081/kWh |
| All Additional | 0.051/kWh |
| General Service - Medium (>30kW & <= 250kW) | |
| Base/Customer Charge | 91.00 |
| Demand Rate | 12.45/kW |
| 1st 500 kWh | $0.0484/\mathrm{kWh}$ |
| All Additional | 0.0457/kWh |
| General Service - Medium (>30kW) - Pumping | |
| Base/Customer Charge | 91.00 |
| Demand Rate | $9.85/\mathrm{kW}$ |
| All kWh | 0.063/kWh |
| General Service - Large (> 250kW) | |
| Base/Customer Charge | 177.00 |
| Demand Rate | 15.10/kW |
| All kWh | 0.045/kWh |

Approved: 12/15/2021 Page 2 of 75

Heber Light & Power Company

2022 Budget – Executive Summary (State Format)

| _ | 2020 Actual | 2021 Budget | 2021 Projected | 2022 Budget |
|----------------------------------|--------------|--------------|----------------|--------------|
| REVENUES | _ | | | |
| Electricity Sales | \$20,255,718 | \$20,955,112 | \$20,866,653 | \$21,730,674 |
| Connect Fees | 37,400 | 35,000 | 34,450 | 35,000 |
| Receivables Penalty Income | 36,588 | 40,000 | 42,326 | 40,000 |
| Other / Miscellaneous Income | 200,459 | 203,069 | 217,870 | 204,200 |
| Total Revenues | \$20,530,165 | \$21,233,181 | \$21,161,198 | \$22,009,874 |
| COST OF ELECTRIC SERVICE | | | | |
| Power Production Expense | (849,307) | (1,071,176) | (1,290,114) | (1,686,019) |
| Cost of Purchased Power | (10,462,883) | (10,810,464) | (10,377,259) | (11,392,745) |
| Dist Expense – Operations | (454,253) | (470,366) | (532,194) | (553,851) |
| Dist Expense – Maintenance | (2,314,752) | (2,267,315) | (2,045,232) | (2,530,868) |
| Customer Account Expense | (502,296) | (751,606) | (493,191) | (556,489) |
| Admin & General Expense | (2,903,422) | (2,421,821) | (2,225,144) | (2,648,961) |
| Total Operating & Maint. Expense | (17,486,913) | (17,792,748) | (16,963,134) | (19,344,783) |
| | | | | |
| Depreciation | (2,325,393) | (2,625,000) | (2,690,501) | (2,860,000) |
| Interest on Long-Term Debt | (665,814) | (901,004) | (558,866) | (547,144) |
| Total Cost of Electric Service | (20,478,120) | (21,318,752) | (20,212,501) | (22,776,077) |
| OPERATION MARGIN | 52,045 | (85,571) | 948,697 | (743,184) |
| Interest Income | 253,314 | 165,000 | 80,745 | 36,000 |
| Non-Operating Margins-Other | 4,703,979 | 3,015,000 | 7,931,499 | 4,515,000 |
| Dividends | (300,000) | (300,000) | (300,000) | (300,000) |
| OPERATING MARGIN | 4,709,338 | 2,794,429 | 8,660,941 | 3,507,816 |
| CAPITAL EXPENDITURES | | | | |
| Generation - Hydro | 54,720 | 25,000 | 2,169 | 15,000 |
| Generation – Gas Plant | 322,785 | 1,250,000 | 1,212,456 | 2,329,000 |
| Distribution | 2,781,296 | 5,810,000 | 7,405,323 | 5,323,000 |
| Substation | (235) | 11,181,000 | 0 | 17,772,000 |
| Metering | 95,231 | 114,400 | 45,000 | 114,400 |
| Buildings | 171,095 | 1,737,085 | 780,000 | 8,982,000 |
| Vehicles | 496,009 | 435,000 | 140,902 | 325,000 |
| Tools | 21,696 | 54,700 | 76,727 | 288,000 |
| Technology – IT | 50,361 | 585,000 | 119,686 | 323,500 |
| Total Capital | 3,993,048 | 21,187,185 | 9,782,263 | 35,471,900 |

Approved: 12/15/2021 Page 3 of 75

Heber Light & Power Company

2022 Budget – Executive Summary (Actuals Format)

| | 2019 Actual | 2020 Actual | 2021 Projected | 2022 Budget | | |
|-----------------------------------|------------------------|------------------------|------------------------|------------------------|--|--|
| REVENUES | \$10.046.457 | \$20.255.710 | \$20.977.75 | \$21.720.674 | | |
| Electricity Sales Connect Fees | \$19,046,457 38,740 | \$20,255,718 37,400 | \$20,866,653 34,450 | \$21,730,674 35,000 | | |
| Receivables Penalty Income | 47,010 | 36,588 | 42,326 | 40,000 | | |
| Other / Miscellaneous Income | 310,749 | 200,459 | 217,870 | 204,200 | | |
| , | | | | | | |
| Total Revenues | \$19,442,956 | \$20,530,165 | \$21,161,198 | \$22,009,874 | | |
| COST OF ELECTRIC SERVICE | | | | | | |
| Power Production Expense | (1,051,780) | (849,307) | (1,290,114) | (1,686,019) | | |
| Cost of Purchased Power | (9,338,094) | (10,462,883) | (10,337,259) | (11,392,745) | | |
| Dist Expense – Operations | (503,399) | (454,253) | (532,194) | (553,851) | | |
| Dist Expense – Maintenance | (2,167,861) | (2,314,752) | (2,045,232) | (2,530,868) | | |
| Customer Account Expense | (405,546) | (502,296) | (493,191) | (556,489) | | |
| Admin & General Expense | (2,029,408) | (2,903,422) | (2,225,144) | (2,648,961) | | |
| Total Operating & Maint. Expense | (15,496,088) | (17,486,913) | (16,963,134) | (19,368,933) | | |
| Depreciation | (2,082,223) | (2,325,393) | (2,690,501) | (2,860,000) | | |
| Interest on Long-Term Debt | (612,779) | (665,814) | (558,866) | (547,144) | | |
| Č . | | | | | | |
| Total Cost of Electric Service | (18,191,090) | (20,478,120) | (20,212,501) | (22,776,077) | | |
| OPERATION MARGIN | 1,251,866 | 52,045 | 948,697 | (776,203) | | |
| Interest Income | 124,000 | 253,314 | 80,745 | 36,000 | | |
| Non-Operating Margins-Other | 3,290,421 | 4,703,979 | 7,931,499 | 4,515,000 | | |
| Dividends | (300,000) | (300,000) | (300,000) | (300,000) | | |
| OPERATING MARGIN | 4,366,287 | 4,709,338 | 8,660,941 | 3,484,797 | | |
| CAPITAL EXPENDITURES | | | | | | |
| Generation - Hydro | 2,120 | 54,720 | 2,169 | 15,000 | | |
| Generation – Gas Plant | 5,481 | 322,785 | 1,212,456 | 2,329,000 | | |
| Distribution | 2,445,072 | 2,781,296 | 7,405,323 | 5,323,000 | | |
| Substation | 155,104 | (235) | 0 | 17,772,000 | | |
| Metering | 30,824 | 95,231 | 45,000 | 114,400 | | |
| Buildings | 82,423 | 171,095 | 780,000 | 8,982,000 | | |
| Vehicles | 24,543 | 496,009 | 140,902 | 325,000 | | |
| Tools | 97,875 | 21,696 | 76,727 | 288,000 | | |
| Technology – IT | 24,586 | 50,361 | 119,686 | 323,500 | | |
| Total Capital | 2,868,028 | 3,993,048 | 9,782,263 | 35,471,900 | | |

Approved: 12/15/2021 Page 4 of 75

Operating Expenditures Budget

Revenues

The 2022 electricity revenues are budgeted to increase 2.7% over the projected 2021 revenues. This represents a conservative estimate for the trended load growth and implementation of a rate increase adopted during 2019.

Revenues associated with Capital in Aid of Construction and Impact Fees are not included as these revenues are not regular and are typically subject to external economic conditions.

| | 2020 Actual | 2021 Budget | 2021 Projected | 2022 Budget | | |
|------------------------------|--------------|----------------|----------------|--------------|--|--|
| REVENUES | | | | | | |
| Electricity Sales | \$20,255,718 | \$20,955,112 | \$20,866,653 | \$21,730,674 | | |
| Connect Fees | 37,400 | 35, 000 | 34,450 | 35,000 | | |
| Receivables Penalty Income | 36,588 | 40,000 | 42,326 | 40,000 | | |
| Other / Miscellaneous Income | 200,459 | 203,069 | 217,870 | 204,200 | | |
| Total Revenues | \$20,530,165 | \$21,233,181 | \$21,161,198 | \$22,009,874 | | |

Expenses

Power Purchased

Power Purchased expense is calculated by analyzing supply requirements, identifying the cost of supply from individual sources and adding contingency pricing for market fluctuations.

Wages and Board Compensation

Included in the wages and board compensation expense are amounts for the current complement of employees.

Board Compensation

| Board Position | Stipend <u>Amount</u> |
|------------------------|--------------------------|
| Chair | 7,295.04 |
| Member 1 | 5,703.84 |
| Member 2 | 5,703.84 |
| Member 3 | 5,703.84 |
| Member 4 | 5,703.84 |
| Member 5 | <u>5,703.84</u> |
| | \$35,814.24 |
| Committee Compensation | 4,185.76 |

Repairs & Maintenance

Repairs and maintenance are anticipated to continue in 2022. Tree trimming costs will significantly increase by \$500,000. Furthermore, the addition of 2 new employees are included in this budget thus increasing the overall maintenance and repair costs.

Travel & Training

To maintain the advanced technical knowledge required in the industry, various training initiatives for staff are included in the 2022 Budget.

Approved: 12/15/2021 Page 5 of 75

Capital Expenditures Budget

The Capital Budget for 2022 totals \$35,471,900. Heber Light & Power anticipates utilizing revenue from energy sales, debt financing, capital in aid of construction and through impact fees to complete the 2022 capital program. In the event these resources are insufficient to meet these anticipated capital addition expenditures, Heber Light & Power has two other payment mechanisms at its disposal. The first, Heber Light & Power can use additional debt-financing in the event additional funds are required to complete the needed capital expansion projects. The second is through reserve accounts of which Heber Light & Power maintains two such funds. The first such fund is a contingency fund with a current balance of roughly \$3.6 million which is available to address certain large capital purchases and /or reserve requirements associated with internal generation, rate stabilization and power market escalation. The second such fund is a capital reserve fund meant to supply quick access to funds in order to complete major projects considered in the Company's current Strategic Plan.

Also included in the table below are principal payments relating to the Company's long-term debt.

| Classification | Expenditure | Impact | <u>CIAC</u> | Net Amount |
|------------------------|--------------------|----------------|--------------|------------|
| Generation - Hydro | 15,000 | - | - | 15,000 |
| Generation – Gas Plant | 2,329,000 | - | - | 2,329,000 |
| Distribution | 5,323,000 | - | (3,000,000) | 2,323,000 |
| Substation | 17,772,000 | (3,800,000) | - | 13,972,000 |
| Metering | 114,400 | - | (96,000) | 18,400 |
| Buildings | 8,982,000 | - | 8,982,000 | |
| Vehicles | 325,000 | - | - | 325,000 |
| Tools | 288,000 | - | - | 288,000 |
| Technology – IT | 323,500 | - | - | 323,500 |
| | Т | otal Capital E | \$28,575,900 | |
| | Principal Paym | ents on Long | 757,665 | |
| | \$29,333,565 | | | |

Detailed capital project descriptions in support of these amounts are included on the following pages.

Approved: 12/15/2021 Page 6 of 75



Buildings

- 1) Generator Fire Suppression System
- 2) New Office Building
- 3) Millflat Water Line Replacement
- 4) Gas Plant Security Upgrades
- 5) Plant AC Upgrades
- 6) Plant Analysis Fallout

Approved: 12/15/2021 Page 7 of 75

Project Analysis Form

Project Name: Generator Fire Suppression System

Project Driver: Safety

Priority Level: Medium

Purpose & Necessity:

Small fires are occasionally generated on and around the generators as a result of the excessive amounts of heat, fuel and available catalysts. As a result, the dispatchers and generation employees are using handheld extinguishing tools to extinguish these fires when they arise. Our insurance reviews are frequently critical of the lack of suppression systems on our generators and thus this project will increase safety as well as increase our insurability.

Plant 1: \$660,963 Plant 2: \$679,000

Plant 3 phase 1: \$626,735 Plant 3 phase 2: \$497,539

Campus Wide Fire A&D System Communication Network: \$40,978

Risk Assessment:

Potential exists to have a major fire that either drastically damages the structure, equipment, or both. The damage can result from the fire itself or from the firefighting methods that will be employed by the local fire department with their water-based fighting technology. A larger risk exists in that employees are typically called upon to be the first line of defense to which they are woefully under supplied and un-trained.

Cash Flow Schedule:

| | 2020 | <u>2021</u> | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>Overall</u> |
|----------------|---------------|---------------|---------------|---------------|---------------|-------------|-----------------|
| Internal Labor | 1,529.67 | 2,077.16 | - | 3,000.00 | 3,000.00 | - | 9,606.83 |
| Materials | 17.25 | 2,749.76 | - | 1,500.00 | 1,500.00 | - | 5,767.01 |
| Subcontractor | 328,191.65 | 292,169.40 | 497,539.00 | 679,000.00 | 660,963.00 | - | 2,457,863.05 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | | | | | | | |
| Subtotal: | \$ 329,738.57 | \$ 296,996.32 | \$ 497,539.00 | \$ 683,500.00 | \$ 665,463.00 | \$ - | \$ 2,473,236.89 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | \$329,738.57 | \$296,996.32 | \$497,539.00 | \$683,500.00 | \$665,463.00 | \$ - | \$2,473,236.89 |

Approved: 12/15/2021 Page 8 of 75

Project Analysis Form

| Project Name: | New Office Building |
|-----------------|---------------------|
| Project Driver: | Upgrade |

Purpose & Necessity:

Priority Level: High

Heber Light & Power has outgrown the existing work space for administrative operations. In addition, the building is older and not ADA compliant. Furthermore the division of Administration from Operations has made communications less-effective between departments. The building is currently surrounded on all four sides with rights-of-ways for other entities which causes expansion limitations. Parking for employees and customers is extremely limited. Finally, numerous secondary elements such as IT structure, and building security cannot be adequately addressed in the current state.

Risk Assessment:

Efficiency is the main advantage to combining all of the administrative functions under one roof. In addition, by remaining non-compliant with appropriate ADA standards, the company remains at risk of not accommodating customer needs. Furthermore the transition to 138kV service in the valley also opens the company to additional cyber-security scrutiny and controls. The current building set-up will require extensive adjustments to obtain compliance with NERC CIPS requirements.

Cash Flow Schedule:

| | <u>2020</u> | <u>2021</u> | <u>2022</u> | <u>2023</u> | | 2 | <u>2024</u> | | <u>025</u> | <u>Overall</u> |
|----------------|-------------|-----------------|-----------------|-------------|---|----|-------------|----|------------|-----------------|
| Internal Labor | 6,527.83 | 1,500.00 | 10,000.00 | | - | | - | | - | 18,027.83 |
| Materials | - | - | - | | - | | - | | - | - |
| Subcontractor | 69,585.60 | 25,000.00 | 8,300,000.00 | | - | | - | | - | 8,394,585.60 |
| Miscellaneous | - | - | - | | - | | - | | - | - |
| (CIAC) Reim | | - | _ | | - | | - | | - | |
| Subtotal: \$ | 76,113.43 | \$ 26,500.00 | \$ 8,310,000.00 | \$ | - | \$ | - | \$ | - | \$ 8,412,613.43 |
| Impact Fee % | 0% | 0% | 0% | | | | | | | |
| Net Amount: \$ | 76,113.43 | \$ 26,500.00 | \$ 8,310,000.00 | \$ | - | \$ | - | \$ | - | \$ 8,412,613.43 |

Approved: 12/15/2021 Page 9 of 75

Project Analysis Form

| Project Name: | Millflat Water Line Replacement |
|-----------------|---------------------------------|
| Project Driver: | Replacement |
| Priority Level: | High |

Purpose & Necessity:

The main water line that feeds the Upper Snake Creek and ultimately the Lower Snake Creek Hydro plants is in serious need of replacement. As it currently stands, the line is old and exposed to damage by vehicles and the Forest Service as they access the upper reaches of Snake Creek Canyon. This project will be completed in unison with Midway Irrigation and as such might be delayed beyond 2022 as it was in 2021.

Risk Assessment:

Risk exists that given the right damage instance, loss of the use of both hydro plants will occur. This loss will lead to the curtailment of production which would then result in replacement energy being purchased on the spot market.

Cash Flow Schedule:

| | <u>2021</u> | <u>2022</u> | <u>20</u> : | <u>23</u> | 20 | <u>)24</u> | <u>20</u> | <u>)25</u> | 2 | <u>026</u> | <u>Overall</u> |
|----------------|-------------|--------------|-------------|-----------|----|------------|-----------|------------|----|------------|-----------------|
| Internal Labor | - | - | | - | | - | | - | | - | - |
| Materials | - | - | | - | | - | | - | | - | - |
| Subcontractor | - | 50,000.00 | | - | | - | | - | | - | 50,000.00 |
| Miscellaneous | - | - | | - | | - | | - | | - | - |
| (CIAC) Reim | - | | | - | | - | | - | | - | - |
| Subtotal: | \$ - | \$ 50,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 50,000.00 |
| Impact Fee % | | 0% | | | | | | | | | 0% |
| Net Amount: | \$ - | \$ 50,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 50,000.00 |

Approved: 12/15/2021 Page 10 of 75

Project Analysis Form

| Project Name: | Gas Plant Security |
|-----------------|--------------------|
| Project Driver: | Upgrade |
| Priority Level: | Medium |

Purpose & Necessity:

HLP has been in the process of installing security access controls on all HLP facilities. The generation plants are the next in line to receive such security upgrades. Some work has been completed in 2021, while others will be required in 2022.

Risk Assessment:

Uncontrolled access is currently available to anyone that is able to penetrate the exterior fence of the campus. Such access could place the generation fleet at an unacceptable level of risk of tampering and potential destruction.

Cash Flow Schedule:

| | <u>2021</u> | <u>2022</u> | 20 | <u>)23</u> | 2 | <u>024</u> | <u> 2025</u> | 2 | <u>026</u> | <u>Overall</u> |
|----------------|-------------|--------------|----|------------|----|------------|--------------|----|------------|-----------------|
| Internal Labor | - | 5,000.00 | | - | | - | - | | - | 5,000.00 |
| Materials | 5,000.00 | 35,000.00 | | - | | - | - | | - | 40,000.00 |
| Subcontractor | - | 10,000.00 | | - | | - | - | | - | 10,000.00 |
| Miscellaneous | - | - | | - | | - | - | | - | - |
| (CIAC) Reim | - | | | - | | - | - | | - | - |
| Subtotal: \$ | 5,000.00 | \$ 50,000.00 | \$ | - | \$ | - | \$ - | \$ | - | \$ 55,000.00 |
| Impact Fee % | 0% | 0% | | | | | | | | 0% |
| Net Amount: \$ | 5,000.00 | \$ 50,000.00 | \$ | - | \$ | - | \$ | \$ | | \$ 55,000.00 |

Approved: 12/15/2021 Page 11 of 75

Project Analysis Form

| Project Name: | Plant AC Upgrades |
|-----------------|-------------------|
| Project Driver: | Upgrade |
| Priority Level: | High |

Purpose & Necessity:

The generation plants are presently cooled through the use of numerous evaporative coolers. These coolers are prone to failure and inefficient due to their advancing age. This project would provide for the replacement of multiple evaporative coolers with a more energy efficient newer evaporative cooler. These updates will happen over the course of multiple years. The first such upgrade happened in 2019. Each year an additional set of coolers will be replaced until all have been taken care of.

Risk Assessment:

Generators require cooling in order to maintain optimal efficiency and reduce the risk of fire caused by excessive heat.

Cash Flow Schedule:

| | 2021 | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>Overall</u> |
|----------------|-----------|--------------|--------------|--------------|-------------|-------------|----------------|
| Internal Labor | 3,433.73 | 2,000.00 | 2,000.00 | 2,000.00 | - | - | 9,433.73 |
| Materials | 1,700.49 | 1,500.00 | 1,500.00 | 1,500.00 | - | - | 6,200.49 |
| Subcontractor | 79,634.98 | 70,000.00 | 80,000.00 | 80,000.00 | - | - | 309,634.98 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | | |
| Subtotal: \$ | 84,769.20 | \$ 73,500.00 | \$ 83,500.00 | \$ 83,500.00 | \$ - | \$ - | \$ 325,269.20 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: \$ | 84,769.20 | \$ 73,500.00 | \$ 83,500.00 | \$ 83,500.00 | \$ - | \$ - | \$ 325,269.20 |

Approved: 12/15/2021 Page 12 of 75

Project Analysis Form

| Project Name: | Plant Analysis Fallouts |
|-----------------|-------------------------|
| Project Driver: | Upgrade |
| Priority Level: | Medium |

Purpose & Necessity:

The development of a new building for HLP as well as the current status of each existing facility lays in wait for finalization of direction from the Board of Directors with respect to the new building. If the new building is to be built, certain existing facilities will need some remodel work, while some structures will need to be removed entirely. This project is a placeholder to be fleshed out a later date. The value presented herein is the estimated amount to safely remove the structures known as Cold Storage and Line Shop assuming the new building is built.

Risk Assessment:

Facilities requiring significant adjustments for operational and safety needs will remain in a state of unfit if this project is not approved.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>20</u> 2 | <u> 24</u> | <u>20</u> | <u>)25</u> | 20 | <u>)26</u> | <u>20</u> | <u>)27</u> | <u>Ov</u> | <u>rerall</u> |
|----------------|-------------|---------------|-------------|------------|-----------|------------|----|------------|-----------|------------|-----------|---------------|
| Internal Labor | - | 5,000.00 | | - | | - | | - | | - | 5 | 5,000.00 |
| Materials | - | - | | - | | - | | - | | - | | - |
| Subcontractor | - | 95,000.00 | | - | | - | | - | | - | 95 | ,000.00 |
| Miscellaneous | - | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | _ | | | - | | - | | - | | - | | - |
| Subtotal: | \$ - | \$ 100,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 100 | ,000.00 |
| Impact Fee % | 0% | 0% | | 0% | | 0% | | 0% | | 0% | | 0% |
| Net Amount: _ | \$ - | \$ 100,000.00 | \$ | - | \$ | | \$ | | \$ | | \$ 100 | ,000.00 |

Approved: 12/15/2021 Page 13 of 75



Generation

- 1) Annual Generation Capital Improvements
- 2) Lower Snake Creek Plant Upgrade
- 3) Upper Snake Creek Capital Improvements
- 4) Lake Creek Capital Improvements
- 5) New Generation Assets
- 6) Unit Overhauls
- 7) Gas Plant 1 Transformer Upgrade
- 8) Gas Plant 2 Transformer Upgrade
- 9) Gas Plant 2 Switchgear
- 10) Gas Plant 2 Radiator
- 11) Gas Plant 2 Mufflers
- 12) Gas Plant 3 Switchgear Upgrade
- 13) Lake Creek Bearing Replacement
- 14) Gas Plant Exhaust Compliance
- 15) Mobile Standby Generator

Approved: 12/15/2021 Page 14 of 75

Project Analysis Form

| Project Name: | Capital Improvements - Generation |
|-----------------|-----------------------------------|
| Project Driver: | Reliability |
| Priority Level: | High |

Purpose & Necessity:

Each year various generation related assets are needed in order to prolong the life, meet additional environmental requirements, and increase capacity. As such a blanket amount is approved in order to increase response time when upgrades are required. Furthermore it eliminates the multiple approvals that could present themselves during the course of a year for minor capital asset additions.

2024 has additional funds for Plant 1 roof replacement, exhaust fans, and a new gas line in Plant 2

Risk Assessment:

Equipment will wear down to a point of non-function thus requiring additional expense to restore them to functionality again. An additional risk is that of an environmental penalty or sanction resulting from tardiness installing needed equipment. The gas line in plant 2 is a fire hazard as presently constituted.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|----------------|--------------|--------------|--------------|--------------|---------------|-------------|----------------|
| Internal Labor | 10,000.00 | 10,000.00 | 10,000.00 | 10,000.00 | 25,000.00 | - | 65,000.00 |
| Materials | 40,000.00 | 40,000.00 | 40,000.00 | 40,000.00 | 175,000.00 | - | 335,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | - | |
| Subtotal: | \$ 50,000.00 | \$ 50,000.00 | \$ 50,000.00 | \$ 50,000.00 | \$ 200,000.00 | \$ - | \$ 400,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | | 0% |
| Net Amount: | \$ 50,000.00 | \$50,000.00 | \$50,000.00 | \$50,000.00 | \$ 200,000.00 | \$ - | \$ 400,000.00 |

Approved: 12/15/2021 Page 15 of 75

Project Analysis Form

Project Name: Lower Snake Creek Plant Upgrade

Project Driver: Reliability

Priority Level: Medium

Purpose & Necessity:

Each year various generation related assets are needed in order to prolong the life, meet additional environmental requirements, and increase capacity. As such a blanket amount is approved in order to increase response time when upgrades are required. Furthermore it eliminates the multiple approvals that could present themselves during the course of a year for minor capital asset additions.

Risk Assessment:

The facility will become unusable and thus eliminate the generating capacity that it provides to our system.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | 2 | 027 | <u>Overall</u> |
|----------------|--------------|----------------|----------------|-------------|-------------|----|-----|-----------------|
| Internal Labor | 1,000.00 | 1,000.00 | 1,000.00 | 1,000.00 | 1,000.00 | | - | 5,000.00 |
| Materials | 14,000.00 | 4,000.00 | 4,000.00 | 4,000.00 | 4,000.00 | | - | 30,000.00 |
| Subcontractor | - | - | - | - | - | | - | - |
| Miscellaneous | - | - | - | - | - | | - | - |
| (CIAC) Reim | | - | - | | | | - | - |
| Subtotal: | \$ 15,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ | - | \$ 35,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | | | |
| Net Amount: | \$15,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ | - | \$ 35,000.00 |

Approved: 12/15/2021 Page 16 of 75

Project Analysis Form

| Project Name: | Upper Snake Creek Plant Upgrade |
|-----------------|---------------------------------|
| Project Driver: | Reliability |
| Priority Level: | Medium |

Purpose & Necessity:

Each year various generation related assets are needed in order to prolong the life, meet additional environmental requirements, and increase capacity. As such a blanket amount is approved in order to increase response time when upgrades are required. Furthermore it eliminates the multiple approvals that could present themselves during the course of a year for minor capital asset additions.

Risk Assessment:

The facility will become unusable and thus eliminate the generating capacity that it provides to our system.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2</u> | 027 | <u>Overall</u> |
|----------------|-------------|----------------|----------------|-------------|-------------|----------|-----|-----------------|
| Internal Labor | 1,000.00 | 1,000.00 | 1,000.00 | 1,000.00 | 1,000.00 | | - | 5,000.00 |
| Materials | 4,000.00 | 4,000.00 | 4,000.00 | 4,000.00 | 4,000.00 | | - | 20,000.00 |
| Subcontractor | - | - | - | - | - | | - | - |
| Miscellaneous | - | - | - | - | - | | - | - |
| (CIAC) Reim | - | - | - | | | | - | - |
| Subtotal: \$ | 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ | - | \$ 25,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | | | |
| Net Amount: | 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ | - | \$ 25,000.00 |

Approved: 12/15/2021 Page 17 of 75

Project Analysis Form

| Project Name: | Lake Creek Improvements |
|-----------------|-------------------------|
| Project Driver: | Reliability |
| Priority Level: | Medium |

Purpose & Necessity:

Each year various generation related assets are needed in order to prolong the life, meet additional environmental requirements, and increase capacity. As such a blanket amount is approved in order to increase response time when upgrades are required. Furthermore it eliminates the multiple approvals that could present themselves during the course of a year for minor capital asset additions.

Risk Assessment:

The facility will become unusable and thus eliminate the generating capacity that it provides to our system.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | 2 | 027 | Overall |
|-----------------|-------------|----------------|----------------|--------------|-------------|----|-----|-----------------|
| Internal Labor | 1,000.00 | 1,000.00 | 1,000.00 | 1,000.00 | 1,000.00 | | - | 5,000.00 |
| Materials | 4,000.00 | 4,000.00 | 4,000.00 | 14,000.00 | 4,000.00 | | - | 30,000.00 |
| Subcontractor | - | - | - | - | - | | - | - |
| Miscellaneous | - | - | - | - | - | | - | - |
| (CIAC) Reim | - | - | - | | | | - | - |
| Subtotal: \$ | 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 15,000.00 | \$ 5,000.00 | \$ | - | \$ 35,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | | | 0% |
| Net Amount: _\$ | 5,000.00 | \$ 5,000.00 | \$ 5,000.00 | \$ 15,000.00 | \$ 5,000.00 | \$ | | \$ 35,000.00 |

Approved: 12/15/2021 Page 18 of 75

Project Analysis Form

| Project Name: | New Generation |
|-----------------|----------------|
| Project Driver: | Growth |
| Priority Level: | Medium |

Purpose & Necessity:

The current generation portfolio will be heavily strained by 2026 without the procurement of other generating sources. Load growth is projected to be regular and consistent. The generator portfolio is used regularly to defer the market risk that is inherent with the increasing resource needs of the company. The company is working with the Caterpillar and Wheeler organizations to install a battery bank in 2022, as well as looking new engines in 2024 and 2025.

Risk Assessment:

Heber Light & Power is regularly attempting to diversify the generation portfolio. Without the acquisition of additional resources, the Company will be forced to purchase more energy from the market at the prevailing rates which may not favor the Company.

Cash Flow Schedule:

| | 2021 | <u>20</u> | <u> 22</u> | 20 | 023 | 2 | <u>024</u> | <u>20</u> | <u> 25</u> | <u>20</u> | <u> 26</u> | <u>O</u> | verall |
|----------------|------|-----------|------------|----|-----|---------|------------|-----------|------------|-----------|------------|----------|-----------|
| Internal Labor | - | 15 | ,000.00 | | - | 1 | 5,000.00 | 15 | ,000.00 | | - | | 45,000.00 |
| Materials | - | 1,250 | ,000.00 | | - | | - | | - | | - | 1,2 | 50,000.00 |
| Subcontractor | - | 50 | ,000.00 | | - | 1,20 | 0,000.00 | 1,285 | ,000.00 | | - | 2,5 | 35,000.00 |
| Miscellaneous | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | - | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ - | \$ 1,315 | 5,000.00 | \$ | - | \$ 1,21 | 5,000.00 | \$ 1,300 | ,000.00 | \$ | - | \$ 3,8 | 30,000.00 |
| Impact Fee % | | | 100% | | | | 100% | | 100% | | | | 100% |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - |

Approved: 12/15/2021 Page 19 of 75

Project Analysis Form

| Project Name: Unit Overhauls | |
|------------------------------|--|
| Project Driver: Reliability | |

Purpose & Necessity:

Priority Level: Medium

The generating units are operated as needed until a requisite number of engine hours have been expired. As a measure of standard preventative maintenance, the engine is taken out of service and the engine is overhauled. The following engines are scheduled to reach their operating hours as follows:

Unit 4 - 2022 Unit 11 - 2023 Unit 1&2 - 2024

Risk Assessment:

Equipment will wear down to a point of non-function thus requiring additional expense to restore them to functionality again. An additional risk is that of an untimely outage of either of these two units. By scheduling the overhaul, control of the outage/loss of production can be managed.

Cash Flow Schedule:

| | <u>2021</u> | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>Overall</u> |
|----------------|-------------|---------------|-----------------|---------------|-------------|-------------|----------------|
| Internal Labor | - | 8,000.00 | 8,000.00 | 8,000.00 | - | - | 24,000.00 |
| Materials | - | - | - | - | - | - | - |
| Subcontractor | - | 180,000.00 | 75,000.00 | 180,000.00 | - | - | 435,000.00 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | - | | - | - | _ |
| Subtotal: | \$ - | \$ 188,000.00 | \$ 83,000.00 | \$ 188,000.00 | \$ - | \$ - | \$ 459,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | \$ - | \$ 188,000.00 | \$ 83,000.00 | \$ 188,000.00 | \$ - | \$ - | \$ 459,000.00 |

Approved: 12/15/2021 Page 20 of 75

Project Analysis Form

Project Name: Gas Plant 1 Transformer Upgrade

Project Driver: Growth

Priority Level: Low

Purpose & Necessity:

Gas Plant 1 currently sits with an open generator bay. Growth in the valley will necessitate the placement of a generator in the vacant position. The current transformer is only rated for 7 MW. Additional generator load will require an upgraded transformer capable of handling 10 MW.

Risk Assessment:

The largest risk associated with the failure to complete this project is the inability to place a needed generator in the open bay of Plant 1. Projected loads will not be adequately met by the company unless the generator portfolio is maintained at the proper level.

Cash Flow Schedule:

| | 2022 | 2 | 2 | <u> 2023</u> | <u>2024</u> | 2 | <u> 2025</u> | <u>20</u> | <u>)26</u> | <u>20</u> | <u>)27</u> | <u>Overall</u> | |
|----------------|------|---|----|--------------|---------------|----|--------------|-----------|------------|-----------|------------|----------------|---|
| Internal Labor | | - | | - | 45,000.00 | | - | | - | | - | 45,000.00 | |
| Materials | | - | | - | 455,000.00 | | - | | - | | - | 455,000.00 | |
| Subcontractor | | - | | - | - | | - | | - | | - | - | |
| Miscellaneous | | - | | - | - | | - | | - | | - | - | |
| (CIAC) Reim | | - | | - | | | - | | - | | - | _ | _ |
| Subtotal: | \$ | - | \$ | - | \$ 500,000.00 | \$ | - | \$ | - | \$ | - | \$ 500,000.00 | |
| Impact Fee % | | | | | 0% | | | | | | | 0% | , |
| Net Amount: | \$ | | \$ | - | \$ 500,000.00 | \$ | - | \$ | - | \$ | - | \$ 500,000.00 | = |

Approved: 12/15/2021 Page 21 of 75

Project Analysis Form

| Project Name: | Gas Plant 2 Transformer Upgrade |
|-----------------|---------------------------------|
| Project Driver: | Growth |
| Priority Level: | Low |

Purpose & Necessity:

Growth in the valley will necessitate the placement of a generator in the vacant position. The current transformer is only rated for 7 MW. Additional generator load will require an upgraded transformer capable of handling 10 MW.

Risk Assessment:

The largest risk associated with the failure to complete this project is the inability to place a needed generator in the open bay of Plant 2. Projected loads will not be adequately met by the company unless the generator portfolio is maintained at the proper level.

Cash Flow Schedule:

| | 022 | 2 | 023 | 2 | 024 | <u>2025</u> | 2 | <u> 2026</u> | <u>2</u> | 027 | <u>Overall</u> |
|----------------|---------|----|-----|----|-----|---------------|----|--------------|----------|-----|----------------|
| Internal Labor | - | | - | | - | 45,000.00 | | - | | - | 45,000.00 |
| Materials | - | | - | | - | 455,000.00 | | - | | - | 455,000.00 |
| Subcontractor | - | | - | | - | - | | - | | - | - |
| Miscellaneous | - | | - | | - | - | | - | | - | - |
| (CIAC) Reim | - | | - | | - | | | - | | - | |
| Subtotal: | \$ - | \$ | - | \$ | - | \$ 500,000.00 | \$ | - | \$ | - | \$ 500,000.00 |
| Impact Fee % | | | | | | 0% | | | | | 0% |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ 500,000.00 | \$ | - | \$ | - | \$ 500,000.00 |

Approved: 12/15/2021 Page 22 of 75

Project Analysis Form

Project Name: Plant 2 Switchgear

Project Driver: Growth

Priority Level: High

Purpose & Necessity:

The switchgear in plant 2 is old and no longer supported with new components. Furthermore, the addition of newer engines in the bays left by units 5 and 6 might be of such a nature that a newer switchgear would be required. With the recent loss of unit 5, the potential has become a reality.

Risk Assessment:

Existing switchgear is no longer suitable.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | 202 | <u>4</u> | <u>2025</u> | <u>2026</u> | | <u>2027</u> | Overall |
|----------------|-------------|-------------|----------|----------|-------------|-------------|----|-------------|-----------------|
| Internal Labor | 5,000.00 | - | | - | - | | | - | 5,000.00 |
| Materials | - | - | | - | - | | | - | - |
| Subcontractor | 55,000.00 | - | | - | - | | | - | 55,000.00 |
| Miscellaneous | - | - | | - | - | | | - | - |
| (CIAC) Reim | - | - | | | - | | | - | - |
| Subtotal: \$ | 60,000.00 | \$ - | \$ | - \$ | - | \$ | \$ | - | \$ 60,000.00 |
| Impact Fee % | 0% | 0% | 6 | 0% | 0% | | 0% | 0% | 0% |
| Net Amount: \$ | 60,000.00 | \$ - | \$ | - \$ | 3 - | \$ - | \$ | <u> </u> | \$ 60,000.00 |

Approved: 12/15/2021 Page 23 of 75

Project Analysis Form

| Project Name: | Plant 2 Radiator |
|-----------------|------------------|
| Project Driver: | Growth |
| Priority Level: | High |

Purpose & Necessity:

The radiators for the remaining engines in Gas Plant 2 are old and of the non-minimal noise type. The replacement of unit 5 with a test unit will require an upgrade of the radiator.

Risk Assessment:

Without upgrading the radiator, the new test unit will not function at the desired test level as well as will provide additional noise pollution within the area.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | Overall |
|----------------|-------------|-------------|-------------|-------------|-------------|-------------|----------------|
| Internal Labor | 5,000.00 | - | - | - | | - | 5,000.00 |
| Materials | - | - | - | - | | - | - |
| Subcontractor | 60,000.00 | - | - | - | - | - | 60,000.00 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | _ | | | | | |
| Subtotal: \$ | 65,000.00 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ 65,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: \$ | 65,000.00 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ 65,000.00 |

Approved: 12/15/2021 Page 24 of 75

Project Analysis Form

Project Name: Plant 2 Mufflers

Project Driver: Growth

Purpose & Necessity:

Priority Level: High

The mufflers on plant 2 are old and no longer meeting the State standards. Furthermore, the addition of newer engines in the bays left by units 5 and 6 might be of such a nature that a newer muffler would be required. With the recent loss of unit 5, the potential has become a reality.

Risk Assessment:

Fail to meet State air requirements.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | Overall |
|-----------------|-------------|-------------|-------------|-------------|-------------|-------------|----------------|
| Internal Labor | 5,000.00 | - | - | - | | - | 5,000.00 |
| Materials | - | - | - | - | | - | - |
| Subcontractor | 50,000.00 | - | - | - | - | - | 50,000.00 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | | |
| Subtotal: \$ | 55,000.00 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ 55,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: _\$ | 55,000.00 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ 55,000.00 |

Approved: 12/15/2021 Page 25 of 75

Project Analysis Form

| Project Name: | Plant 3 Switchgear Upgrade |
|-----------------|----------------------------|
| Project Driver: | Upgrade |
| Priority Level: | High |

Purpose & Necessity:

The switchgear system in Plant 3 will no longer be adequate to operate effectively to protect the generators within Plant 3. This project will upgrade the switchgear for SCADA controlled protection scheme.

Risk Assessment:

In the event a system failure occurs, the generators in Plant 3 are protected only by an outdated system. Thus the generators could be significantly damaged if an event happens on the grid.

Cash Flow Schedule:

| Out I I I I I I I I I I I I I I I I I I I | 2022 | <u>20</u> | <u>23</u> | 20 | 024 | 2 | <u>025</u> | 2 | 026 | 2 | 027 | <u>Overall</u> |
|---|---------------|-----------|-----------|----|-----|----|------------|----|-----|----|-----|----------------|
| Internal Labor | 5,000.00 | | - | | - | | - | | - | | - | 5,000.00 |
| Materials | - | | - | | - | | - | | - | | - | - |
| Subcontractor | 225,000.00 | | - | | - | | - | | - | | - | 225,000.00 |
| Miscellaneous | - | | - | | - | | - | | - | | - | - |
| (CIAC) Reim | - | | - | | - | | | | - | | - | _ |
| Subtotal: | \$ 230,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 230,000.00 |
| Impact Fee % | 0% | | 0% | | 0% | | 0% | | 0% | | 0% | |
| Net Amount: | \$ 230,000.00 | \$ | - | \$ | - | \$ | - | \$ | | \$ | | \$ 230,000.00 |

Approved: 12/15/2021 Page 26 of 75

Project Analysis Form

| Project Name: | Lake Creek Bearing Replacement |
|-----------------|--------------------------------|
| Project Driver: | Upgrade |
| Priority Level: | High |
| Priority Level: | High |

Purpose & Necessity:

The bearing on the Lake Creek plant is showing signs of aging and normal wear. In order to extend the life of this plant, the bearing will need to be replaced.

Risk Assessment:

In the event a system failure occurs, the generator at the Lake Creek Hydro Plant will be offline. Thus the low-cost generator would not be supplying its regular energy at its reduced rate. Higher cost unplanned market energy would need to be secured to fill the hole in supply.

Cash Flow Schedule:

| | <u>2022</u> | 2 | <u> 2023</u> | <u>20</u> | <u>)24</u> | <u>2025</u> | <u>20</u> | <u> 26</u> | 2 | <u>027</u> | <u>Overall</u> |
|----------------|-------------|----|--------------|-----------|------------|--------------|-----------|------------|----|------------|-----------------|
| Internal Labor | - | | - | | - | 2,000.00 | | - | | - | 2,000.00 |
| Materials | - | | - | | - | 8,000.00 | | - | | - | 8,000.00 |
| Subcontractor | - | | - | | - | - | | - | | - | - |
| Miscellaneous | - | | - | | - | - | | - | | - | - |
| (CIAC) Reim | - | | - | | - | | | - | | - | - |
| Subtotal: | \$ - | \$ | - | \$ | - | \$ 10,000.00 | \$ | - | \$ | - | \$ 10,000.00 |
| Impact Fee % | | | | | | 0% | | | | | |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ 10,000.00 | \$ | - | \$ | - | \$ 10,000.00 |

Approved: 12/15/2021 Page 27 of 75

Project Analysis Form

| Project Name: | Gas Plant Exhaust Compliance (WO 10813) |
|-----------------|---|
| Project Driver: | Upgrade |
| Priority Level: | Medium |

Purpose & Necessity:

A recent emission review by the State of Utah as a result of the Unit 13 Generator purchase, has determined that HLP is no longer meeting State guidelines for plant emissions. As such a recommendation of increasing the height of the generator smoke stacks to a height of 55 feet will get the company into compliance.

Risk Assessment:

No ability to run the gas plants due to the emission non-compliance.

Cash Flow Schedule:

| CHOIL LIO II CONCER | 101 | | | | | | | | | | |
|---------------------|---------------|----|------------|----------|-----|----|------|--------------|----|------------|----------------|
| | <u>2022</u> | 20 | <u>)23</u> | <u>2</u> | 024 | 2 | 2025 | <u> 2026</u> | 2 | <u>027</u> | Overall |
| Internal Labor | 5,000.00 | | - | | - | | - | | | - | 5,000.00 |
| Materials | - | | - | | - | | - | | | - | - |
| Subcontractor | 225,000.00 | | - | | - | | - | - | | - | 225,000.00 |
| Miscellaneous | - | | - | | - | | - | - | | - | - |
| (CIAC) Reim | _ | | - | | - | | - | - | | - | |
| Subtotal: | \$ 230,000.00 | \$ | - | \$ | - | \$ | - | \$ - | \$ | - | \$ 230,000.00 |
| Impact Fee % | 0% | | | | | | | | | | |
| Net Amount: | \$ 230,000.00 | \$ | | \$ | - | \$ | - | \$ - | \$ | | \$ 230,000.00 |

Approved: 12/15/2021 Page 28 of 75

Project Analysis Form

Project Name: Mobile Standby Generator Purchase

Project Driver: Reliability

Priority Level: Medium

Purpose & Necessity:

In coordination with the Heber City Corporation, HLP will be purchasing a mobile 1MW standby generator. This generator would be dispatched by either the Heber City Corporation or HLP to needed locations during periods of upheaval on the system.

Risk Assessment:

Critical infratructure such as water pumps or critical facilties such as rest homes or emergency back-up locations would need energy in critical outages due to multiple scenarios. This unit would be used to secure the energy for these critical locations until energy can be restored.

Cash Flow Schedule:

| _ | <u>2021</u> | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>Overall</u> |
|----------------|-------------|--------------|-------------|-------------|-------------|-------------|----------------|
| Internal Labor | - | 1,000.00 | - | - | - | - | 1,000.00 |
| Materials | - | 130,000.00 | - | - | - | - | 130,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | (65,000.00) | | | | | (65,000.00) |
| Subtotal: \$ | - | \$ 66,000.00 | \$ - | \$ - | \$ - | \$ - | \$ 66,000.00 |
| Impact Fee % | | 0% | | | | | 0% |
| Net Amount: \$ | | \$66,000.00 | \$ - | \$ - | \$ - | \$ - | \$ 66,000.00 |

Approved: 12/15/2021 Page 29 of 75



Distribution

- 1) Cross-Valley Transmission Line (2nd POI)
- 2) Underground System Improvements
- 3) Aged & Environmental Distribution Replacement / Upgrade
- 4) Fault Indicator Underground System
- 5) Rebuild PR 201: Main Street to Burgi Lane
- 6) Additional Circuits out of Jailhouse to the East
- 7) Additional Circuits out of College to South and East
- 8) Install Voltage Regulators at Timber Lakes Gate
- 9) Heber Substation Additional Circuits (South & West)
- 10) Reconductor HB305_600 West Substation to 300 South
- 11) Midway Substation Get Aways
- 12) Load to Parsons (Reconductor)
- 13) Reconductor Heber City Main Street: 600 South to 1000 South
- 14) Jailhouse Tap T-Line and East Extension
- 15) Reconductor Pine Canyon Road Midway
- 16) Reconductor JH 502/503: Old Mill Drive 800 South to 1200 South
- 17) Reconductor MW 101/102: 4/0 to 477
- 18) Rebuild CL 402: 600 West to Tate Lane
- 19) Tie Line from 305 to 402 to 303
- 20) Tie from 702 up to 500 East in Heber (HB304)

Approved: 12/15/2021 Page 30 of 75

Project Analysis Form

| Project Name: | Cross-Valley Transmission Line (2nd POI) |
|-----------------|--|
| Project Driver: | Upgrade |
| Priority Level: | High |

Purpose & Necessity:

The transmission system that is currently used to energize the HLP distribution system is undersized and aged in most locations. This project will replace those structures that are in an advanced state of pre-failure while increasing capacity for the next quarter-century.

Risk Assessment:

The conductor itself will be out of capacity in the next 5 years as a result of regional growth. A risk of prolonged outage as a result of failure due to aged and dilapidated poles is also present.

Cash Flow Schedule:

| | <u>2018</u> | <u>2019</u> | <u>2020</u> | <u>2021</u> | <u>2022</u> | <u>2023</u> | <u>Overall</u> |
|----------------|-------------|--------------|---------------|-----------------|-----------------|-------------|-----------------|
| Internal Labor | 497.87 | 19,134.91 | 46,735.07 | 331,801.46 | - | - | 398,169.31 |
| Materials | - | - | 309,479.91 | 388,420.50 | - | - | 697,900.41 |
| Subcontractor | 3,830.05 | 56,637.70 | 78,623.48 | 1,370,693.61 | - | - | 1,509,784.84 |
| Miscellaneous | - | - | - | - | 3,955,000.00 | - | 3,955,000.00 |
| (CIAC) Reim | - | | | | | | |
| Subtotal: | \$ 4,327.92 | \$ 75,772.61 | \$ 434,838.46 | \$ 2,090,915.57 | \$ 3,955,000.00 | \$ - | \$ 6,560,854.56 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 100% |
| Net Amount: | \$ 4,327.92 | \$ 75,772.61 | \$ 434,838.46 | \$ 2,090,915.57 | \$ 3,955,000.00 | \$ - | \$ 6,560,854.56 |

Approved: 12/15/2021 Page 31 of 75

Project Analysis Form

Project Name: Underground System Improvements

Project Driver: Reliability

Priority Level: Low

Purpose & Necessity:

Underground equipment becomes subject to the elements and thus begin to show signs of aging and breakdown. Thus HL&P monitors the underground equipment for aging and periodically retires worn out assets by replacing them.

Risk Assessment:

By refusing to correct the installation issues in the underground assets, HL&P is at risk of unintentional outages and potential hazardous conditions for both employees and customers.

Cash Flow Schedule:

| <u> </u> | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|----------------|--------------|--------------|--------------|--------------|--------------|--------------|----------------|
| Internal Labor | 17,000.00 | 17,000.00 | 17,000.00 | 17,000.00 | 17,000.00 | 17,000.00 | 102,000.00 |
| Materials | 33,000.00 | 33,000.00 | 33,000.00 | 33,000.00 | 33,000.00 | 33,000.00 | 198,000.00 |
| Subcontractor | 25,000.00 | 25,000.00 | 25,000.00 | 25,000.00 | 25,000.00 | 25,000.00 | 150,000.00 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | | | | | | | |
| Subtotal: | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$ 450,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$ 75,000.00 | \$450,000.00 |

Approved: 12/15/2021 Page 32 of 75

Project Analysis Form

Project Name: Aged & Environmental Distribution Replacement/Upgrade

Priority Level: Medium

Purpose & Necessity:

Project Driver: Reliability

Distribution poles are subject to aging and decomposition. In addition, the equipment framing on some of the structures are of such an age in which proper safeguards were not put into to place to ensure raptor protection and safety. After having recently completed an avian study on the entire system as well as a pole density test on 50% of the system, it is imperative that replacement structures are installed in place of those identified as failing on either of the two studies.

Risk Assessment:

By refusing to correct the failing structures, HL&P is at risk of unintentional outages and potential hazardous conditions for both employees, customers, and wildlife.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|----------------|---------------|---------------|---------------|---------------|---------------|---------------|----------------|
| Internal Labor | 20,000.00 | 20,000.00 | 20,000.00 | 20,000.00 | 20,000.00 | 20,000.00 | 120,000.00 |
| Materials | 130,000.00 | 130,000.00 | 130,000.00 | 130,000.00 | 130,000.00 | 130,000.00 | 780,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | _ | | | _ | | | |
| Subtotal: | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$ 900,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$ 150,000.00 | \$900,000.00 |

Approved: 12/15/2021 Page 33 of 75

Project Analysis Form

Project Name: Fault Indicator - Underground System

Project Driver: Reliability

Priority Level: Low

Purpose & Necessity:

Underground equipment becomes subject to the elements and thus begin to show signs of aging and breakdown. Thus HL&P monitors the underground equipment for aging and periodically retires worn out assets by replacing them. This project would put into place an annual amount that can be added to the system to help identify where faults are occurring on the underground portions of the distribution schedule.

Risk Assessment:

By refusing to correct the installation issues in the underground assets, HL&P is at risk of unintentional outages and potential hazardous conditions for both employees and customers.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|----------------|--------------|--------------|--------------|--------------|--------------|--------------|----------------|
| Internal Labor | 2,000.00 | 2,000.00 | 2,000.00 | 2,000.00 | 2,000.00 | 2,000.00 | 12,000.00 |
| Materials | 8,000.00 | 8,000.00 | 8,000.00 | 8,000.00 | 8,000.00 | 8,000.00 | 48,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | | |
| Subtotal: | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 60,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 60,000.00 |

Approved: 12/15/2021 Page 34 of 75

Project Analysis Form

Project Name: Reconductor Provo River 201 (Main Street to Burgi Lane)

Project Driver: Reliability

Priority Level: High

Purpose & Necessity:

The current circuit engineering study has demonstrated that the stretch of Provo River 201 from Main Street to Burgi Lane will be undersized after 2021. In order to remedy this issue, the circuit will need to be reconductored through this section of the line.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage. This project will achieve N-1 standard on this circuit. It is currently below this standard and as such the system reliability is at risk.

Cash Flow Schedule:

| | <u>2022</u> | <u>20</u> | <u>23</u> | <u>20</u> | 024 | 2 | 025 | 20 | <u>026</u> | <u>20</u> | 027 | | Overall |
|----------------|---------------|-----------|-----------|-----------|-----|----|-----|----|------------|-----------|-----|----|------------|
| Internal Labor | 100,000.00 | | - | | - | | - | | - | | - | | 100,000.00 |
| Materials | 671,000.00 | | - | | - | | - | | - | | - | (| 671,000.00 |
| Subcontractor | - | | - | | - | | - | | - | | - | | - |
| Miscellaneous | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ 771,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | 771,000.00 |
| Impact Fee % | 100% | | | | | | | | | | | | 100% |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | |

Approved: 12/15/2021 Page 35 of 75

Project Analysis Form

| Project Name: | Additional Circuits out of Jailhouse to the East |
|-----------------|--|
| Project Driver: | Growth |
| Priority Level: | Medium |

Purpose & Necessity:

The development of the South end of Heber City, and the East side of Wasatch County have necessitated additional circuits out of the Jailhouse Substation.

Risk Assessment:

Insufficient capacity to serve the numerous additional customers seeking service on the South side of Heber City and the East side of Wasatch County. This project is 100% customer driven and thus it has slipped from year to year as the development is still pending.

Cash Flow Schedule:

| | 2019 | <u>2020</u> | <u> 2021</u> | | <u>2022</u> | 2 | 023 | 20 | <u>024</u> | <u>Ov</u> | <u>erall</u> |
|----------------|---------------|-------------|--------------|-------|-------------|--------|---------|----|------------|-----------|--------------|
| Internal Labor | 56,000.00 | - | - | 2 | 28,000.00 | 28 | ,000.00 | | - | 112 | 2,000.00 |
| Materials | 224,000.00 | - | - | 1 | 12,000.00 | 112 | ,000.00 | | - | 448 | 3,000.00 |
| Subcontractor | - | - | | | - | | - | | - | | - |
| Miscellaneous | - | - | - | | - | | - | | - | | - |
| (CIAC) Reim | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ 280,000.00 | \$ - | \$ - | \$ 14 | 40,000.00 | \$ 140 | ,000.00 | \$ | - | \$ 560 | ,000.00 |
| Impact Fee % | 100% | | | | 100% | | 100% | | | | 100% |
| Net Amount: | \$ - | \$ - | \$ - | \$ | | \$ | | \$ | | \$ | - |

Approved: 12/15/2021 Page 36 of 75

Project Analysis Form

| Project Name: | Additional Circuits out of College to South and East |
|-----------------|--|
| Project Driver: | Growth |
| Priority Level: | High |
| Purpose & Nec | cessity: |

The development of the North end of Heber City has necessitated additional circuits out of the College Substation.

Risk Assessment:

Insufficient capacity to serve the numerous additional customers seeking service on the North side of Heber City. This project is 100% customer driven and thus it has slipped from year to year as the development is still pending.

Cash Flow Schedule:

| | 2022 | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|----------------|------|-----------------|---------------|-------------|-------------|-------------|-----------------|
| Internal Labor | - | 100,000.00 | 25,000.00 | - | - | - | 125,000.00 |
| Materials | - | 1,110,000.00 | 179,000.00 | - | - | - | 1,289,000.00 |
| Subcontractor | - | 140,000.00 | - | - | - | - | 140,000.00 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | _ | | | |
| Subtotal: | \$ - | \$ 1,350,000.00 | \$ 204,000.00 | \$ - | \$ - | \$ - | \$ 1,554,000.00 |
| Impact Fee % | | 100% | 100% | | | | 100% |
| Net Amount: | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |

Approved: 12/15/2021 Page 37 of 75

Project Analysis Form

| Project Name: | Install Voltage Regulators at Timber Lakes Gate |
|-----------------|---|
| Project Driver: | Reliability |
| Priority Level: | Medium |

Purpose & Necessity:

The continual growth in the Timber Lakes Subdivision along with the relative distance from the Jailhouse substation has the voltage within the subdivision subject to irregular fluctuations. These irregularities create a power quality issue for HLP customers.

Risk Assessment:

By refusing to correct the installation issues in the Timber Lakes Subdivision, customer satisfaction will decrease. In addition, customer equipment stands the chance of being damaged thus driving up insurance claims and premiums.

Cash Flow Schedule:

| | <u>2022</u> | 2 | <u>023</u> | <u>20</u> | <u> 24</u> | <u>20</u> | <u>)25</u> | <u>20</u> | <u> 26</u> | <u>20</u> | <u> 27</u> | Ove | <u>erall</u> |
|----------------|---------------|----|------------|-----------|------------|-----------|------------|-----------|------------|-----------|------------|---------|--------------|
| Internal Labor | 15,000.00 | | - | | - | | - | | - | | - | 15, | 00.000 |
| Materials | 85,000.00 | | - | | - | | - | | - | | - | 85, | 00.000 |
| Subcontractor | - | | - | | - | | - | | - | | - | | - |
| Miscellaneous | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ 100,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 100, | 00.000 |
| Impact Fee % | 100% | | | | | | | | | | | | 0% |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ | | \$ | | \$ | - | \$ | |

Approved: 12/15/2021 Page 38 of 75

Project Analysis Form

Project Name: Heber Substation Additional Circuits (South & West)

Project Driver: Upgrade

Priority Level: Medium

Purpose & Necessity:

The system continues to grow and require additional feeders out of the substation. The recent addition of the 2nd transformer will facilitate the future energization of these feeders. These feeders will also facilitate the switching efforts required during outages, thus minimizing customer inconvenience.

Risk Assessment:

Stranded energy as a result of the excess capacity brought on by the 2nd transformer in 2016/2017. Lengthened outages due to lack of looped feed on different circuits. Overloaded circuits of existing feeders as a result of continued growth in the area.

Cash Flow Schedule:

| | <u>2022</u> | <u>2</u> | 023 | <u>2</u> | 024 | 2 | 2025 | 20 | 026 | 20 | 027 | <u>(</u> | <u>Overall</u> |
|----------------|---------------|----------|-----|----------|-----|----|------|----|-----|----|-----|----------|----------------|
| Internal Labor | 55,000.00 | | - | | - | | - | | - | | - | | 55,000.00 |
| Materials | 225,000.00 | | - | | - | | - | | - | | - | 2 | 25,000.00 |
| Subcontractor | - | | - | | - | | - | | - | | - | | - |
| Miscellaneous | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | - | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ 280,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 2 | 80,000.00 |
| Impact Fee % | 100% | | | | | | | | | | | | 100% |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - |

Approved: 12/15/2021 Page 39 of 75

Project Analysis Form

Project Name: Reconductor Heber 305 (600 West Substation to 300 South)

Project Driver: Reliability

Priority Level: High

Purpose & Necessity:

The current circuit engineering study has demonstrated that the stretch of Heber 305 from the Substation to 300 South along 600 West will be undersized after 2021. In order to remedy this issue, the circuit will need to be reconductored through this section of the line.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage. This project will achieve N-1 standard on this circuit. It is currently below this standard and as such the system reliability is at risk.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2</u> (| <u>025</u> | 20 | 026 | 20 | 027 | Overall |
|----------------|--------------|-------------|-------------|------------|------------|----|-----|----|-----|-----------------|
| Internal Labor | 12,000.00 | - | - | | - | | - | | - | 12,000.00 |
| Materials | 55,000.00 | - | - | | - | | - | | - | 55,000.00 |
| Subcontractor | - | - | - | | - | | - | | - | - |
| Miscellaneous | - | - | - | | - | | - | | - | - |
| (CIAC) Reim | - | | - | | - | | - | | - | - |
| Subtotal: | \$ 67,000.00 | \$ - | \$ - | \$ | - | \$ | - | \$ | - | \$ 67,000.00 |
| Impact Fee % | 100% | | | | | | | | | 100% |
| Net Amount: | \$ - | \$ - | \$ - | \$ | - | \$ | - | \$ | - | \$ - |

Approved: 12/15/2021 Page 40 of 75

Project Analysis Form

Project Name: Midway Substation - Get Aways

Project Driver: Upgrade

Purpose & Necessity:

Priority Level: High

The current get aways from the Midway Substation are becoming undersized and aged. This project will replace the existing get aways with new, more appropriately sized conductor and other necessary equipment.

Risk Assessment:

Imminent failure due to the age and under-sized nature of the existing get aways. Outage and repair efforts will be determined by the type of failure which could be extensive.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | 2 | <u>025</u> | 20 | 026 | 20 | 027 | <u>Overall</u> |
|----------------|-------------|---------------|-------------|----|------------|----|-----|----|-----|------------------|
| Internal Labor | - | 32,000.00 | - | | - | | - | | - | 32,000.00 |
| Materials | - | 128,000.00 | - | | - | | - | | - | 128,000.00 |
| Subcontractor | - | - | - | | - | | - | | - | - |
| Miscellaneous | - | - | - | | - | | - | | - | - |
| (CIAC) Reim | - | | - | | - | | - | | - | - |
| Subtotal: | \$ - | \$ 160,000.00 | \$ - | \$ | - | \$ | - | \$ | - | \$ 160,000.00 |
| Impact Fee % | | 50% | | | | | | | | 50% |
| Net Amount: | \$ - | \$ 80,000.00 | \$ - | \$ | - | \$ | - | \$ | - | \$ 80,000.00 |

Approved: 12/15/2021 Page 41 of 75

Project Analysis Form

| Project Name: | Load to Parsons (Reconductor) |
|-----------------|-------------------------------|
| Project Driver: | Upgrade |
| Priority Level: | High |

Purpose & Necessity:

The feeder line that supplies energy to the Parson Gravel Pit and equipment is undersized and will need to be upgraded.

Risk Assessment:

The customer has expensive equipment that requires regular and stable voltage at higher levels to satisfy their needs. If the line voltage drops, the customer stands to experience damaged equipment increasing the risk to HLP of expensive insurance claims.

Cash Flow Schedule:

| | | 2022 | 24 | 20.4 | • | 005 | 2 | 000 | _ | | 0 11 |
|----------------|-------------|---------------|----|-------------|----------|------------|----|------------|----|-------------|----------------|
| | <u>2022</u> | <u>2023</u> | 20 | <u> 024</u> | <u>2</u> | <u>025</u> | 2 | <u>026</u> | 2 | <u> 027</u> | <u>Overall</u> |
| Internal Labor | - | 15,000.00 | | - | | - | | - | | - | 15,000.00 |
| Materials | - | 85,000.00 | | - | | - | | - | | - | 85,000.00 |
| Subcontractor | - | - | | - | | - | | - | | - | - |
| Miscellaneous | - | - | | - | | - | | - | | - | - |
| (CIAC) Reim | - | | | - | | - | | - | | - | |
| Subtotal: | \$ - | \$ 100,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 100,000.00 |
| Impact Fee % | | 0% | | | | | | | | | 0% |
| Net Amount: | \$ - | \$ 100,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 100,000.00 |

Approved: 12/15/2021 Page 42 of 75

Project Analysis Form

Project Name: Reconductor Heber City Main Street - 600 S - 1000 S Project Driver: Upgrade Priority Level: Low Purpose & Necessity:

Growth on the south end of Heber City has began to exceed the acceptable conductor size for the existing assets. In order to continue to provide uninterrupted service along this feeder, the conductor needs to be upgraded.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage. This project will achieve N-1 standard on this circuit. It is currently below this standard and as such the system reliability is at risk.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u> </u> | <u>2025</u> | <u>2026</u> | 2 | 027 | <u>Overall</u> |
|----------------|-------------|---------------|-------------|----------|-------------|-------------|----|-----|----------------|
| Internal Labor | - | 15,000.00 | | - | - | - | | - | 15,000.00 |
| Materials | - | 85,000.00 | | - | - | - | | - | 85,000.00 |
| Subcontractor | - | - | | - | - | - | | - | - |
| Miscellaneous | - | - | | - | - | - | | - | - |
| (CIAC) Reim | - | | | | - | - | | - | |
| Subtotal: | \$ - | \$ 100,000.00 | \$ | - | \$ - | \$ - | \$ | - | \$ 100,000.00 |
| Impact Fee % | | | | | | | | | |
| Net Amount: | \$ - | \$ 100,000.00 | \$ | | \$ - | \$ - | \$ | - | \$ 100,000.00 |

Approved: 12/15/2021 Page 43 of 75

Project Analysis Form

| Project Name: | Jailhouse Tap Transmission Line and East Extension |
|-----------------|--|
| Project Driver: | Growth |
| Priority Level: | Medium |

Purpose & Necessity:

Growth on the East side of Heber City will begin to exceed the capacity of the existing substations within the next decade. This project will expand the transmission infrastructure to the East allowing for the development of an Eastern Substation.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage.

Cash Flow Schedule:

| | 2022 | 2 | 2023 | 2024 | <u> </u> | 2 | 025 | 2 | 026 | 2 | 027 | <u>o</u> | verall |
|----------------|------|----|------|-------------|----------|----|-----|----|-----|----|-----|----------|-----------|
| Internal Labor | - | | - | 250,00 | 00.00 | | - | | - | | - | 2. | 50,000.00 |
| Materials | - | | - | 3,650,00 | 00.00 | | - | | - | | - | 3,6. | 50,000.00 |
| Subcontractor | - | | - | | - | | - | | - | | - | | - |
| Miscellaneous | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | - | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ - | \$ | - | \$ 3,900,00 | 00.00 | \$ | - | \$ | - | \$ | - | \$ 3,9 | 00,000.00 |
| Impact Fee % | | | | | 100% | | | | | | | | 100% |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - |

Approved: 12/15/2021 Page 44 of 75

Project Analysis Form

Project Name: Reconductor Pine Canyon Road - Midway

Project Driver: Upgrade

Priority Level: Low

Purpose & Necessity:

Growth in the vicinity of Pine Canyon Road has began to exceed the acceptable conductor size for the existing assets. In order to continue to provide uninterrupted service along this feeder, the conductor needs to be upgraded.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage. This project will achieve N-1 standard on this circuit. It is currently below this standard and as such the system reliability is at risk.

Cash Flow Schedule:

| | 2 | 022 | 2 | 2023 | <u>2024</u> | 2 | 2025 | 2 | <u>026</u> | 2 | 027 | <u>Overall</u> |
|----------------|----|-----|----|------|---------------|----|------|----|------------|----|-----|------------------|
| Internal Labor | | - | | - | 36,000.00 | | - | | - | | - | 36,000.00 |
| Materials | | - | | - | 144,000.00 | | - | | - | | - | 144,000.00 |
| Subcontractor | | - | | - | - | | - | | - | | - | - |
| Miscellaneous | | - | | - | - | | - | | - | | - | - |
| (CIAC) Reim | | - | | - | | | - | | - | | - | - |
| Subtotal: | \$ | - | \$ | - | \$ 180,000.00 | \$ | - | \$ | - | \$ | - | \$ 180,000.00 |
| Impact Fee % | | | | | 60% | | | | | | | 60% |
| Net Amount: | \$ | - | \$ | - | \$ 72,000.00 | \$ | - | \$ | - | \$ | - | \$ 72,000.00 |

Approved: 12/15/2021 Page 45 of 75

Project Analysis Form

Project Name: Reconductor Jailhouse 502/503 (Old Mill Drive from 800 S to 1200 S)

Project Driver: Reliability

Priority Level: Low

Purpose & Necessity:

The current circuit engineering study has demonstrated that the stretch of Jailhouse 502/503 along Old Mill Drive from 800 South to 1200 South will be undersized after 2024. In order to remedy this issue, the circuit will need to be reconductored through this section of the line.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage. This project will achieve N-1 standard on this circuit. It is currently below this standard and as such the system reliability is at risk.

Cash Flow Schedule:

| | <u>202</u> : | <u>2</u> | 2 | 023 | 2 | 2024 | 2 | 025 | <u>2</u> | <u>026</u> | 2 | 2027 | <u>(</u> | <u>Overall</u> |
|----------------|--------------|----------|----|-----|----|------|----|-----|----------|------------|----|------|----------|----------------|
| Internal Labor | | - | | - | | - | | - | 29 | ,000.00 | | - | | 29,000.00 |
| Materials | | - | | - | | - | | - | 500 | ,000.00 | | - | 5 | 00,000.00 |
| Subcontractor | | - | | - | | - | | - | | - | | - | | - |
| Miscellaneous | | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | | - | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ | - | \$ | - | \$ | - | \$ | - | \$ 529 | ,000.00 | \$ | - | \$ 5 | 29,000.00 |
| Impact Fee % | | | | | | | | | | 100% | | | | 100% |
| Net Amount: | \$ | - | \$ | - | \$ | - | \$ | - | \$ | | \$ | - | \$ | _ |

Approved: 12/15/2021 Page 46 of 75

Project Analysis Form

Project Name: Reconductor Midway 101/102 from 4/0 to 477

Project Driver: Reliability

Priority Level: Low

Purpose & Necessity:

The current circuit engineering study has demonstrated that the Midway 101/102 circuits will be undersized after 2024. In order to remedy this issue, the circuit will need to be reconductored.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage. This project will achieve N-1 standard on this circuit. It is currently below this standard and as such the system reliability is at risk.

Cash Flow Schedule:

| | 202 | 22 | 2 | 023 | 2 | 2024 | <u>2</u> | <u>025</u> | 2 | 026 | 2 | 2027 | <u>C</u> | <u> Overall</u> |
|----------------|-----|----|----|-----|----|------|----------|------------|----|-----|----|------|----------|-----------------|
| Internal Labor | | - | | - | | - | 38 | ,000.00 | | - | | - | | 38,000.00 |
| Materials | | - | | - | | - | 800 | ,000.00 | | - | | - | 8 | 00,000.00 |
| Subcontractor | | - | | - | | - | 100 | ,000.00 | | - | | - | 1 | 00,000.00 |
| Miscellaneous | | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | | - | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ | - | \$ | - | \$ | - | \$ 938 | ,000.00 | \$ | - | \$ | - | \$ 9. | 38,000.00 |
| Impact Fee % | | | | | | | | 100% | | | | | | 100% |
| Net Amount: | \$ | - | \$ | - | \$ | - | \$ | | \$ | - | \$ | - | \$ | - |

Approved: 12/15/2021 Page 47 of 75

Project Analysis Form

Project Name: Reconductor Cloyes 402 (600 West to Tate Lane)

Project Driver: Reliability

Priority Level: Low

Purpose & Necessity:

The current circuit engineering study has demonstrated that the stretch of Cloyes 402 from 600 West to Tate Lane will be undersized after 2024. In order to remedy this issue, the circuit will need to be reconductored through this section of the line.

Risk Assessment:

Failure of the existing assets will result in outages with a high likelihood of a prolonged outage. This project will achieve N-1 standard on this circuit. It is currently below this standard and as such the system reliability is at risk.

Cash Flow Schedule:

| | 20 | <u>)22</u> | 2 | 2023 | 2 | <u>024</u> | <u>20</u> : | <u> 25</u> | 2 | <u>026</u> | 2 | <u>027</u> | Ov | <u>erall</u> |
|----------------|----|------------|----|------|----|------------|-------------|------------|----|------------|----|------------|---------|--------------|
| Internal Labor | | - | | - | | - | 100, | ,000.00 | | - | | - | 10 | 0,000.00 |
| Materials | | - | | - | | - | 1,196 | ,000.00 | | - | | - | 1,19 | 6,000.00 |
| Subcontractor | | - | | - | | - | | - | | - | | - | | - |
| Miscellaneous | | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | | - | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ | - | \$ | - | \$ | - | \$ 1,296 | ,000.00 | \$ | - | \$ | - | \$ 1,29 | 6,000.00 |
| Impact Fee % | | | | | | | | 100% | | | | | | 100% |
| Net Amount: | \$ | - | \$ | - | \$ | - | \$ | | \$ | | \$ | | \$ | |

Approved: 12/15/2021 Page 48 of 75

Project Analysis Form

Project Name: New Circuit to Hwy 32

Project Driver: Growth

Priority Level: Medium

Purpose & Necessity:

As a result of the North Annexation of land from the existing boundaries to Hwy 32 by Heber City in 2021, a new circuit will need to be taken from the College Substation to Hwy 32.

Risk Assessment:

HLP is currently relying upon the Jordanelle circuit to carry the load of the Holmes Homes Subdivision on Jordanelle Ridge. A double risk exists in that the distribution load could put strain on the line causing a disruption at the Hydro plant, or issues at the plant could impact the loads on the distribution circuit.

Cash Flow Schedule:

| | 2022 | <u>2023</u> | <u>2024</u> | <u> </u> | 2025 | | <u>2026</u> | 20 | <u>027</u> | | <u>Overall</u> |
|----------------|------|---------------|-------------|----------|------|----|-------------|----|------------|------|----------------|
| Internal Labor | - | 50,000.00 | | - | - | | - | | - | | 50,000.00 |
| Materials | - | 550,000.00 | | - | - | | - | | - | ī | 550,000.00 |
| Subcontractor | - | 120,000.00 | | - | - | | - | | - | | 120,000.00 |
| Miscellaneous | - | - | | - | - | | - | | - | | - |
| (CIAC) Reim | - | | | | - | | - | | | | - |
| Subtotal: | - | \$ 720,000.00 | \$ | - | \$ - | \$ | - | \$ | - | \$ 7 | 720,000.00 |
| Impact Fee % | 100% | 100% | 10 | 00% | 100 |)% | 100% | | 100% | | 100% |
| Net Amount: | \$ - | \$ - | \$ - | | \$ - | \$ | | \$ | - | \$ | |

Approved: 12/15/2021 Page 49 of 75

Project Analysis Form

| Project Name: | Tie From 305 to 402 to 303 |
|-----------------|----------------------------|
| Project Driver: | Growth |
| Priority Level: | High |

Purpose & Necessity:

This tie will provide the company with additional looped feeders for future redundant system needs. Timing and scope of the developer driven projects on the North side of Heber City make this project difficult to estimate timing and cost.

Risk Assessment:

Without completing this tie, an outage could drive an extended outage in particular sections of the system as redundant loops would not be in place to allow for switching efforts.

Cash Flow Schedule:

| | 2 | <u> 2020</u> | 2 | <u> 2021</u> | 4 | <u> 2022</u> | 2 | <u> 2023</u> | 2 | <u> 2024</u> | 2 | 2025 | <u>O</u> | <u>verall</u> |
|----------------|----|--------------|----|--------------|----|--------------|----|--------------|----|--------------|----|------|----------|---------------|
| Internal Labor | | - | | - | | - | | - | | - | | - | | - |
| Materials | | - | | - | | - | | - | | - | | - | | - |
| Subcontractor | | - | | - | | - | | - | | - | | - | | - |
| Miscellaneous | | - | | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | | - | | - | | _ | | - | | - | | - | | - |
| Subtotal: | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - |
| Impact Fee % | | 100% | | 100% | | 100% | | 100% | | 100% | | 100% | | 100% |
| Net Amount: | \$ | | \$ | | \$ | | \$ | | \$ | | \$ | | \$ | |

Approved: 12/15/2021 Page 50 of 75

Project Analysis Form

| Project Name: | Tie From 702 up to 500 East in Heber (HB304) |
|-----------------|--|
| Project Driver: | Growth |
| Priority Level: | Medium |

Purpose & Necessity:

This tie will complete a necessary loop on the North end of Heber City to enhance the system reliability brought upon by the growth in that area of the system.

By completing this project, the customer intends on providing an easement to enable the building of this line.

Timing and scope of the developer driven projects on the North side of Heber City make this project difficult to estimate timing and cost.

Risk Assessment:

Without completing this tie, an outage in North Heber City could result in an extended outage due to the current strain on the system capacity. A series of careful switching maneuvers would be necessary to shed the load sufficient to bring this area back online while increasing the risk of failure in other areas of the system. This project is 100% customer driven and thus it has slipped from year to year as the development is still pending.

Cash Flow Schedule:

| | 2 | <u> 2021</u> | 2 | 2022 | 2 | <u> 2023</u> | 4 | <u> 2024</u> | <u> 2025</u> | 2 | <u> 2026</u> | <u>(</u> | <u>Overall</u> |
|----------------|----|--------------|----|------|----|--------------|----|--------------|--------------|----|--------------|----------|----------------|
| Internal Labor | | - | | - | | - | | - | - | | - | | - |
| Materials | | - | | - | | - | | - | - | | - | | - |
| Subcontractor | | - | | - | | - | | - | - | | - | | - |
| Miscellaneous | | - | | - | | - | | - | - | | - | | - |
| (CIAC) Reim | | - | | - | | - | | - | - | | - | | - |
| Subtotal: | \$ | - | \$ | - | \$ | - | \$ | - | \$ - | \$ | - | \$ | - |
| Impact Fee % | | 100% | | 100% | | 100% | | 100% | 100% | | 100% | | 100% |
| Net Amount: | \$ | | \$ | | \$ | _ | \$ | | \$ | \$ | _ | \$ | |

Approved: 12/15/2021 Page 51 of 75



Substation

- 1) 2nd Point of Interconnect
- 2) Replacement Recloser for Joslyn Reclosers
- 3) Substation Bird Guard
- 4) East Substation
- 5) Cloyes LTC Rebuild
- 6) Provo River Substation Rebuild
- 7) Battery Replacement Program
- 8) Midway Substation High Side Rebuild
- 9) Heber Relay Upgrade
- 10) Jailhouse Lease Buyout or Extension
- 11) Jailhouse Fence Replacement

Approved: 12/15/2021 Page 52 of 75

Project Analysis Form

| Project Name: | 2nd Point of Interconnect Substation(POI) |
|----------------|---|
| Project Driver | Growth |

Priority Level: High

Purpose & Necessity:

Growth within the system has been steadily increasing for numerous years. The system is currently fed off of a single point of interconnect to the RMP system. This point of interconnect is fed from a radial (meaning single line) service line. In addition the transformer at the end of the radial line is quickly becoming undersized for the local load on our system. This project will provide a second interconnect substation thus reducing the loading on the existing substation transformer. Numerous engineering studies have been conducted on the system and each has drawn the conclusion that the current system will be over-capacity by 2022 at the latest.

Risk Assessment:

This point of interconnect has two significant risks associated with it; 1) risk of damage to the radial feed thus causing immediate outages to all customers, and 2) interconnect site is currently sized to be out of capacity by 2022. If the single interconnect transformer becomes overloaded, RMP will begin to remove load form the transformer which will result in regular prolonged rolling brown-outs. All customers in the system will have a daily outage lasting up to 6 hours during peak load windows.

Cash Flow Schedule:

| | <u>2018</u> | <u>2019</u> | <u>2020</u> | <u>2021</u> | <u>2022</u> | 20 | 023 | <u>Overall</u> |
|----------------|--------------|-----------------|--------------|---------------|------------------|----|-----|------------------|
| Internal Labor | 11,096.15 | 36,073.50 | 30,737.89 | 24,072.04 | 100,000.00 | | - | 201,979.58 |
| Materials | - | - | - | 752.04 | - | | - | 752.04 |
| Subcontractor | 66,658.85 | 61,826.73 | 61,784.00 | 428,483.00 | 10,200,000.00 | | - | 10,818,752.58 |
| Miscellaneous | - | 2,100,000.00 | - | 50,000.00 | 1,620,000.00 | | - | 3,770,000.00 |
| (CIAC) Reim | | | | | | | - | |
| Subtotal: | \$ 77,755.00 | \$ 2,197,900.23 | \$ 92,521.89 | \$ 503,307.08 | \$ 11,920,000.00 | \$ | - | \$ 14,791,484.20 |
| Impact Fee % | | 91% | | 70% | 70% | | | 70% |
| Net Amount: | \$ 77,755.00 | \$ 197,811.02 | \$ 92,521.89 | \$ 150,992.12 | \$ 3,576,000.00 | \$ | - | \$ 14,791,483.50 |

Approved: 12/15/2021 Page 53 of 75

Project Analysis Form

Project Name: Replacement Recloser for Joslyn Reclosers

Project Driver: Replacement

Priority Level: Medium

Purpose & Necessity:

HL&P has a series of Joslyn Reclosers that have historically been less than reliable. The company has been swapping out these reclosers as they fail so as to maximize the usage of these reclosers. This program will spread the cost of replacement of these defective reclosers across multiple years.

Risk Assessment:

Without a spare recloser, a failure of one of the remaining Joslyn Reclosers will see a prolonged outage for a series of HL&P circuits.

Cash Flow Schedule:

| | <u>2022</u> | 2 | 2023 | <u>2</u> | 024 | 2 | 2025 | <u>2</u> | <u>026</u> | 2 | <u>027</u> | Overall |
|----------------|--------------|----|------|----------|-----|----|------|----------|------------|----|------------|-----------------|
| Internal Labor | - | | - | | - | | - | | - | | - | - |
| Materials | 25,000.00 | | - | | - | | - | | | | | 25,000.00 |
| Subcontractor | - | | - | | - | | - | | - | | - | - |
| Miscellaneous | - | | - | | - | | - | | - | | - | - |
| (CIAC) Reim | | | - | | - | | - | | - | | - | - |
| Subtotal: | \$ 25,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 25,000.00 |
| Impact Fee % | 0% | | 0% | | | | | | | | | 0% |
| Net Amount: | \$ 25,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 25,000.00 |

Approved: 12/15/2021 Page 54 of 75

Project Analysis Form

| Project Name: | Substation Bird Guard |
|-----------------|-----------------------|
| Project Driver: | Safety |
| Priority Level: | High |

Purpose & Necessity:

In order to be more environmentally friendly, the company is undertaking efforts to add protective devices where reasonable. To be completed in phases by substation as follows:

2021 - Cloyes 2022 - Jailhouse

Risk Assessment:

Higher than necessary mortality rates of wildlife accidentally located within the substation. Increased number of outages resulting from accidental wildlife exposure to the energized elements of the system.

Cash Flow Schedule:

| | <u>2021</u> | <u>2022</u> | <u>20</u> | 023 | <u>2</u> | <u>024</u> | 2 | <u>025</u> | 2 | <u>026</u> | Overall |
|----------------|-------------|-------------|-----------|-----|----------|------------|----|------------|----|------------|----------------|
| Internal Labor | 1,200.00 | 600.00 | | - | | - | | - | | - | 1,800.00 |
| Materials | 4,800.00 | 2,400.00 | | - | | - | | - | | - | 7,200.00 |
| Subcontractor | - | - | | - | | - | | - | | - | - |
| Miscellaneous | - | - | | - | | - | | - | | - | - |
| (CIAC) Reim | - | | | - | | - | | - | | - | - |
| Subtotal: \$ | 6,000.00 | \$ 3,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 9,000.00 |
| Impact Fee % | 0% | 0% | | 0% | | 0% | | | | | |
| Net Amount: \$ | 6,000.00 | \$3,000.00 | \$ | - | \$ | | \$ | - | \$ | - | \$ 9,000.00 |

Approved: 12/15/2021 Page 55 of 75

Project Analysis Form

| Project Name: | East Substation | | |
|-----------------|-----------------|---|--|
| Project Driver: | Growth | _ | |
| Priority Level: | Medium | | |

Purpose & Necessity:

Due to the regular growth and the planned development on the East side of the valley, additional capacity will be required by 2024. This project will include the siting, permitting, design, and construction of a new system load substation.

2021: Land Purchase 2023: Substation Build

Risk Assessment:

Lack of substation capacity in the Lake Creek area will put the system at risk of overloaded circuits and existing equipment ultimately leading to rolling brown outs across the valley.

Cash Flow Schedule:

| | <u>2021</u> | <u>202</u> | <u>22</u> | 2 | <u>023</u> | <u>2</u> | <u>024</u> | <u>20</u> | <u>)25</u> | <u>20</u> | <u> 26</u> | Ov | <u>erall</u> |
|----------------|---------------|------------|-----------|----|------------|----------|------------|-----------|------------|-----------|------------|----------|--------------|
| Internal Labor | - | | - | | - | | - | | - | 125 | ,000.00 | 12. | 5,000.00 |
| Materials | - | | - | | - | | - | | - | 2,500 | ,000.00 | 2,500 | 0,000.00 |
| Subcontractor | - | | - | | - | | - | | - | 2,397 | ,000.00 | 2,39 | 7,000.00 |
| Miscellaneous | 750,000.00 | | - | | - | | - | | - | | - | 750 | 0,000.00 |
| (CIAC) Reim | - | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ 750,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 5,022 | ,000.00 | \$ 5,772 | 2,000.00 |
| Impact Fee % | 100% | | | | | | | | | | 100% | | 100% |
| Net Amount: | \$ - | \$ | - | \$ | - | \$ | - | \$ | | \$ | - | \$ | |

Approved: 12/15/2021 Page 56 of 75

Project Analysis Form

Project Name: Cloyes LTC Rebuild

Project Driver: Reliability

Priority Level: Low

Purpose & Necessity:

The Load Tap Changer (LTC) in a transformer allows automatic adjustment of voltage regulation. The Cloyes LTC needs to be rebuilt due to age and wear.

Risk Assessment:

Automatic voltage regulation of the transformer will fail during different loading scenarios. This will ultimately result in an outage so as to protect the assets.

Cash Flow Schedule:

| | <u>20</u> 2 | <u> 22</u> | 4 | <u> 2023</u> | <u>2024</u> | 2 | <u> 2025</u> | 20 | 026 | 2 | 027 | <u>Overall</u> |
|----------------|-------------|------------|----|--------------|--------------|----|--------------|----|-----|----|-----|-----------------|
| Internal Labor | | - | | - | 8,000.00 | | - | | - | | - | 8,000.00 |
| Materials | | - | | - | 32,000.00 | | - | | - | | - | 32,000.00 |
| Subcontractor | | - | | - | - | | - | | - | | - | - |
| Miscellaneous | | - | | - | - | | - | | - | | - | - |
| (CIAC) Reim | | - | _ | - | _ | | - | | - | | - | - |
| Subtotal: | \$ | - | \$ | - | \$ 40,000.00 | \$ | - | \$ | - | \$ | - | \$ 40,000.00 |
| Impact Fee % | | | | | | | | | | | | 0% |
| Net Amount: | \$ | - | \$ | - | \$ 40,000.00 | \$ | - | \$ | - | \$ | - | \$ 40,000.00 |

Approved: 12/15/2021 Page 57 of 75

Project Analysis Form

Project Name: Provo River Substation Rebuild

Project Driver: Reliability

Priority Level: Medium

Purpose & Necessity:

Provo River Substation currently serves limited load due to the age and reliability of the equipment. This project will rebuild the substation increasing its reliability.

Two options exist and being considered by HLP staff: 1) rebuild in current location; 2) include in the new 2nd POI site and then bring the feeders out and down the highway to the existing feeder connections at the current Provo River Substation.

Risk Assessment:

Outages in excess of necessity will result by keeping system control limited to current assets.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | 2 | <u> 2024</u> | 2 | <u>025</u> | 20 | <u>)26</u> | 2 | <u>027</u> | <u>(</u> | <u>Overall</u> |
|----------------|-----------------|--------------|----|--------------|----|------------|----|------------|----|------------|----------|----------------|
| Internal Labor | 125,000.00 | - | | - | | - | | - | | - | | 125,000.00 |
| Materials | 2,500,000.00 | - | | - | | - | | - | | - | 2, | 500,000.00 |
| Subcontractor | 2,339,000.00 | 71,000.00 | | - | | - | | - | | - | 2,4 | 410,000.00 |
| Miscellaneous | - | - | | - | | - | | - | | - | | - |
| (CIAC) Reim | _ | | | - | _ | - | | - | | - | | - |
| Subtotal: | \$ 4,964,000.00 | \$ 71,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ 5,0 | 035,000.00 |
| Impact Fee % | 100% | 100% | | | | | | | | | | 100% |
| Net Amount: | \$ - | \$ - | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - |

Approved: 12/15/2021 Page 58 of 75

Project Analysis Form

| Project Name: | Battery Replacement Program |
|-----------------|-----------------------------|
| Project Driver: | Replacement |

Purpose & Necessity:

Priority Level: Low

The batteries in Plant 2 will have reached their cycle life in 2022. The batteries at College Substation and the Lower Snake Creek Plant will reach their life cycle end in 2024. This project will see that they are replaced.

Risk Assessment:

Battery systems provide back-up energy for black start in the event of a system transmission failure. Without them, the generator will not have energy sufficient to come online. These batteries also serve as a back-up to the switchgear equipment for similar purposes.

Cash Flow Schedule:

| | <u>2022</u> | 2 | 023 | <u>2024</u> | <u>2025</u> | <u>202</u> | <u> 26</u> | <u>20</u> | 027 | <u>Overall</u> |
|----------------|-------------|----|-----|--------------|-------------|------------|------------|-----------|-----|-----------------|
| Internal Labor | 1,500.00 | | - | 3,000.00 | 1,000.00 | | - | | - | 5,500.00 |
| Materials | 8,000.00 | | - | 16,000.00 | 7,000.00 | | - | | - | 31,000.00 |
| Subcontractor | - | | - | - | - | | - | | - | - |
| Miscellaneous | - | | - | - | - | | - | | - | - |
| (CIAC) Reim | | | - | | | | - | | - | - |
| Subtotal: | \$ 9,500.00 | \$ | - | \$ 19,000.00 | \$ 8,000.00 | \$ | - | \$ | - | \$ 36,500.00 |
| Impact Fee % | | | | | | | | | | 0% |
| Net Amount: | \$ 9,500.00 | \$ | | \$ 19,000.00 | \$8,000.00 | \$ | - | \$ | - | \$ 36,500.00 |

Approved: 12/15/2021 Page 59 of 75

Project Analysis Form

Project Name: Midway Substation - High Side Rebuild

Project Driver: Growth

Priority Level: Low

Purpose & Necessity:

The Midway Substation has slowly taken on more load until it has reached its capacity on the high-side of the transformer. It is estimated that by 2022 the high-side will need to be rebuilt to serve the loads being placed on the transformer.

Risk Assessment:

The high side of the transformer is the side receiving energy from the grid. If the feed to the transformer is compromised, a prolonged outage will be experienced on the substation thus affecting all of the circuits.

Cash Flow Schedule:

| | 2022 | <u>20</u> | 23 | <u>2024</u> | 2 | <u>025</u> | <u>20</u> | 026 | 2 | 027 | <u>Overall</u> |
|----------------|------|-----------|----|-----------------|----|------------|-----------|-----|----|-----|-----------------|
| Internal Labor | - | | - | 100,000.00 | | - | | - | | - | 100,000.00 |
| Materials | - | | - | 2,556,000.00 | | - | | - | | - | 2,556,000.00 |
| Subcontractor | - | | - | - | | - | | - | | - | - |
| Miscellaneous | - | | - | - | | - | | - | | - | - |
| (CIAC) Reim | - | | - | | | - | | - | | - | |
| Subtotal: | \$ - | \$ | - | \$ 2,656,000.00 | \$ | - | \$ | - | \$ | - | \$ 2,656,000.00 |
| Impact Fee % | | | | 90% | | | | | | | 90% |
| Net Amount: | \$ - | \$ | - | \$ 265,600.00 | \$ | - | \$ | - | \$ | - | \$ 265,600.00 |

Approved: 12/15/2021 Page 60 of 75

Project Analysis Form

Project Name: Heber Relay Upgrade

Project Driver: Replacement

Priority Level: Medium

Purpose & Necessity:

The equipment in the substations and generation plants are controlled by a computer like device called a relay. These relays have a potential to fail without notice and have no real preventative maintenance options. The relays in the Heber Substation are an older version no longer supported after 2024.

Risk Assessment:

Without the upgrade of these relays, the Heber Substation will not be properly monitored and controlled by the Dispatch department. Lack of proper monitoring and supervisory control creates serious risk to life and equipment.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u> 2027</u> | <u>Overall</u> |
|----------------|-------------|-------------|--------------|-------------|-------------|--------------|----------------|
| Internal Labor | - | - | - | - | _ | - | - |
| Materials | - | - | 20,000.00 | - | _ | - | 20,000.00 |
| Subcontractor | - | - | 5,000.00 | - | - | - | 5,000.00 |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | | _ |
| Subtotal: | \$ - | \$ - | \$ 25,000.00 | \$ - | \$ - | \$ - | \$ 25,000.00 |
| Impact Fee % | | | | | | | 0% |
| Net Amount: | \$ - | \$ - | \$ 25,000.00 | \$ - | \$ - | \$ - | \$ 25,000.00 |

Approved: 12/15/2021 Page 61 of 75

Project Analysis Form

| Project Name: | Jailhouse Lease Buyout or Extension |
|-----------------|-------------------------------------|
| Project Driver: | Reliability |
| Priority Level: | Low |

Purpose & Necessity:

When the Jailhouse Substation was originally built, it was placed on land owned by Wasatch County. A lease agreement between HLP and Wasatch County was entered into at the time. As the lease term is drawing to a close, HLP would prefer to outright procure the parcel as opposed to renew the lease. The preference will be to purchase the land but a renewed lease will be settled upon if agreement can't be reached on purchase terms and price.

Risk Assessment:

The first risk is that a lease will need to be re-entered into and a renewal will not be granted in the future. Thus the overall risk will be realized in that the substation will need to be relocated and the costs of doing such is far greater than that of purchasing the land outright.

Cash Flow Schedule:

| | <u>2022</u> | 2 | 023 | 20 | <u>024</u> | 2 | 2025 | 2 | 026 | <u>2</u> | 027 | 9 | <u>Overall</u> |
|----------------|---------------|----|-----|----|------------|----|------|----|-----|----------|-----|------|----------------|
| Internal Labor | 2,500.00 | | - | | - | | - | | - | | - | | 2,500.00 |
| Materials | - | | - | | - | | - | | - | | | | - |
| Subcontractor | 12,000.00 | | - | | - | | - | | - | | - | | 12,000.00 |
| Miscellaneous | 85,500.00 | | - | | - | | - | | - | | - | | 85,500.00 |
| (CIAC) Reim | | | - | | - | | - | | - | | - | | - |
| Subtotal: | \$ 100,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 1 | 00,000.00 |
| Impact Fee % | | | | | | | | | | | | | 0% |
| Net Amount: | \$ 100,000.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 1 | 00,000.00 |

Approved: 12/15/2021 Page 62 of 75

Project Analysis Form

| Project Name: | Jailhouse Fence Replacement |
|-----------------|-----------------------------|
| Project Driver: | Replacement |

Purpose & Necessity:

Priority Level: Low

The jailhouse substation currently has a chain-link fence that prohibits unauthorized access. This fence is subject to high winds and regularly requires maintenance and occasional replacement of portions. A new fence more suited to handling the wind and other environmental factors while meeting the security and operational needs would be installed as part of this project. The current fence is 790 linear feet long.

Risk Assessment:

The company will continue to spend OMAG dollars on maintaining a fence that is truly not the correct type of fence for the designed purpose. With inadequate security as a result of this fence, the company has an increased risk of liability for injury or life lost. Furthermore risk exists that critical infrastructure might be damaged leading to extended outages affecting customers.

Cash Flow Schedule:

| | 20 | 022 | 2 | 023 | 2 | <u>024</u> | <u>2025</u> | 2 | <u> 2026</u> | 2 | <u>027</u> | <u>Overall</u> |
|----------------|----|-----|----|-----|----|------------|---------------|----|--------------|----|------------|----------------|
| Internal Labor | | - | | - | | - | 10,000.00 | | - | | - | 10,000.00 |
| Materials | | - | | - | | - | - | | - | | - | - |
| Subcontractor | | - | | - | | - | 119,000.00 | | - | | - | 119,000.00 |
| Miscellaneous | | - | | - | | - | - | | - | | - | - |
| (CIAC) Reim | | - | | - | | - | | | - | | - | |
| Subtotal: | \$ | - | \$ | - | \$ | - | \$ 129,000.00 | \$ | - | \$ | - | \$ 129,000.00 |
| Impact Fee % | | | | | | | | | | | | 0% |
| Net Amount: | \$ | - | \$ | - | \$ | - | \$ 129,000.00 | \$ | - | \$ | | \$ 129,000.00 |

Approved: 12/15/2021 Page 63 of 75



Information Technology

- 1) IT Upgrades
- 2) OT Upgrades
- 3) Smart Grid Investment
- 4) AMI North Tower

Approved: 12/15/2021 Page 64 of 75

Project Analysis Form

| Project Name: 2022 Capital Improvements - IT | |
|--|--|
| Project Driver: Reliability | |

Purpose & Necessity:

Priority Level: Medium

The following collective list of minor capital assets are various technology components that will be purchased over 2022 for installation:

- Computer Replacement Program... \$50,000

Risk Assessment:

These assets help HL&P to safely manage and maintain the system and each component carries its own risk if failure to secure said item happens.

Cash Flow Schedule:

| | 2022 | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | Overall |
|----------------|-----------|--------------|--------------|--------------|--------------|--------------|----------------|
| Internal Labor | 5,000.00 | 10,000.00 | 2,000.00 | 5,000.00 | 2,000.00 | 5,000.00 | 29,000.00 |
| Materials | 45,000.00 | 75,000.00 | 20,000.00 | 39,000.00 | 20,000.00 | 39,000.00 | 238,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | | |
| Subtotal: \$ | 50,000.00 | \$ 85,000.00 | \$ 22,000.00 | \$ 44,000.00 | \$ 22,000.00 | \$ 44,000.00 | \$ 267,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | 50,000.00 | \$ 85,000.00 | \$ 22,000.00 | \$ 44,000.00 | \$22,000.00 | \$44,000.00 | \$ 267,000.00 |

Approved: 12/15/2021 Page 65 of 75

Project Analysis Form

Project Name: 2022 Capital Improvements - OT

Project Driver: Reliability

Priority Level: Medium

Purpose & Necessity:

The following collective list of minor capital assets are various technology components that will be purchased over 2022 for installation:

- SCADA System Upgrades... \$30,000

Risk Assessment:

These assets help HL&P to safely manage and maintain the system and each component carries its own risk if failure to secure said item happens.

Cash Flow Schedule:

| Oddin 1 10 W Odnoba | 101 | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|---------------------|-----|-------------|--------------|--------------|-----------------|-----------------|--------------|----------------|
| Internal Labor | | 6,000.00 | 6,000.00 | 6,000.00 | 6,000.00 | 6,000.00 | 6,000.00 | 36,000.00 |
| Materials | | 24,000.00 | 24,000.00 | 24,000.00 | 24,000.00 | 24,000.00 | 24,000.00 | 144,000.00 |
| Subcontractor | | - | - | - | - | - | - | - |
| Miscellaneous | | - | - | - | - | - | - | - |
| (CIAC) Reim | | - | | | - | - | | |
| Subtotal: | \$ | 30,000.00 | \$ 30,000.00 | \$ 30,000.00 | \$ 30,000.00 | \$ 30,000.00 | \$ 30,000.00 | \$ 180,000.00 |
| Impact Fee % | | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | \$ | 30,000.00 | \$30,000.00 | \$ 30,000.00 | \$ 30,000.00 | \$ 30,000.00 | \$ 30,000.00 | \$ 180,000.00 |

Approved: 12/15/2021 Page 66 of 75

Project Analysis Form

Project Name: Fiber Improvements

Project Driver: Growth

Priority Level: Medium

Purpose & Necessity:

With the advanced equipment that HLP regularly installs on the system, the need for more advanced and clear communication continues to expand. Additional components need to be installed in order to match the new technology and the company communication needs.

Risk Assessment:

Equipment will not communicate either effectively or timely, thus leaving the system vulnerable to failures or delayed recovery from such.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|----------------|-------------|--------------|--------------|--------------|-------------|-------------|----------------|
| Internal Labor | 3,000.00 | 3,000.00 | 3,000.00 | 3,000.00 | - | - | 12,000.00 |
| Materials | 17,000.00 | 17,000.00 | 17,000.00 | 17,000.00 | - | - | 68,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | _ | _ | | |
| Subtotal: \$ | 20,000.00 | \$ 20,000.00 | \$ 20,000.00 | \$ 20,000.00 | \$ - | \$ - | \$ 80,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | | | 0% |
| Net Amount: \$ | 20,000.00 | \$20,000.00 | \$ 20,000.00 | \$ 20,000.00 | \$ - | \$ - | \$ 80,000.00 |

Approved: 12/15/2021 Page 67 of 75

Project Analysis Form

Project Name: 2021 Smart Grid Investment

Project Driver: Growth

Priority Level: Medium

Purpose & Necessity:

Electrical utilities are connected to a grid of assets established to transfer and supply energy where needed. Technological advances continue to make additional control features available in an automated format. These automated features are otherwise known as Smart Grid. For the foreseeable future, HLP anticipates needing funds to implement these annual Smart Grid adjustments in order to appropriately serve our customers' needs.

Risk Assessment:

The grid technology is advancing so quickly that without concentrated effort on the incorporation of these changes, HLP will be operating in a risk scenario or will ultimately require a significant grid upgrade investment later.

Cash Flow Schedule:

| | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | Overall |
|----------------|-------------|--------------|--------------|--------------|--------------|-------------|----------------|
| Internal Labor | 2,000.00 | 2,000.00 | 2,000.00 | 2,000.00 | 2,000.00 | - | 10,000.00 |
| Materials | 8,000.00 | 8,000.00 | 8,000.00 | 8,000.00 | 8,000.00 | - | 40,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | | |
| Subtotal: \$ | 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ - | \$ 50,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | | 0% |
| Net Amount:\$ | 10,000.00 | \$10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ 10,000.00 | \$ - | \$ 50,000.00 |

Approved: 12/15/2021 Page 68 of 75

Project Analysis Form

| Project Name: AMI North Tower | | |
|-------------------------------|---|--|
| Project Driver: Growth | _ | |
| Priority Level: High | | |

Purpose & Necessity:

The recent annexation plan approval by Heber City Corporation has also expanded the potential customer territory for Heber Light & Power. As developers begin to establish buildable lots within this annexed area, HLP will begin to deploy meters for the collection and relay of usage data. In order to have these meters communicate the data, a new AMI tower will need to be erected with the appropriate equipment.

Risk Assessment:

Without installing this critical antenna, HLP will not be able to read the meter data within the newly annexed service territory.

Cash Flow Schedule:

| | <u>2021</u> | <u>2022</u> | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>Overall</u> |
|----------------|-------------|--------------|-------------|-------------|-------------|-------------|----------------|
| Internal Labor | - | 10,000.00 | - | - | - | - | 10,000.00 |
| Materials | - | 60,000.00 | - | - | - | - | 60,000.00 |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | - | - | - | - | - | - | - |
| (CIAC) Reim | - | | | | | | |
| Subtotal: | - | \$ 70,000.00 | \$ - | \$ - | \$ - | \$ - | \$ 70,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | | 0% |
| Net Amount: | \$ - | \$70,000.00 | \$ - | \$ - | \$ - | \$ - | \$ 70,000.00 |

Approved: 12/15/2021 Page 69 of 75



Tools / Equipment

1) 2022 Annual Program

Approved: 12/15/2021 Page 70 of 75

Project Analysis Form

Project Name: 2022 Capital Improvements - Tools

Project Driver: Replacement

Priority Level: Medium

Purpose & Necessity:

The following collective list of tools are planned to be purchased over 2022:

-Substation

- Substation Tools\$6,000

- Distribution

- Trimble GPS Unit\$11,000

- Hoist and Grips (2) \$6,000 (3,000 each)

- Facilities

- Manlift (65 foot) \$85,000

- Telescoping Boom Forklift \$180,000

Risk Assessment:

These tools are required in order to keep the various crews working efficiently and safely.

Cash Flow Schedule:

| | 2022 | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> |
|----------------|---------------|---------------|--------------|--------------|--------------|--------------|----------------|
| Internal Labor | - | | - | - | - | - | - |
| Materials | - | - | - | - | - | - | - |
| Subcontractor | - | - | - | - | - | - | - |
| Miscellaneous | 288,000.00 | 105,000.00 | 45,000.00 | 45,000.00 | 45,000.00 | 45,000.00 | 573,000.00 |
| (CIAC) Reim | _ | | _ | | | | |
| Subtotal: | \$ 288,000.00 | \$ 105,000.00 | \$ 45,000.00 | \$ 45,000.00 | \$ 45,000.00 | \$ 45,000.00 | \$ 573,000.00 |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Net Amount: | \$288,000.00 | \$ 105,000.00 | \$ 45,000.00 | \$45,000.00 | \$ 45,000.00 | \$ 45,000.00 | \$ 573,000.00 |

Approved: 12/15/2021 Page 71 of 75



Vehicles

1) 2022 Annual Program

Approved: 12/15/2021 Page 72 of 75

Project Analysis Form

| Project Name: 2022 Capital Improvements - Vehicle |
|---|
|---|

Project Driver: Replacement

Priority Level: Medium

Purpose & Necessity:

The following vehicles are planned to be purchased in 2022:

- One(1) Digger Derrick Line Truck (\$300,000) Replaces truck 206 International Bucket Truck (2021 replacement caught up by delayed deliveries)
- One (1) Flat bed trailer (25,000)

Risk Assessment:

These vehicles are deemed necessary to adequately service the territory. These vehicle purchases are meant to replace existing vehicles that have reached their useful life based upon company policy.

Cash Flow Schedule:

| | 2022 | <u>2023</u> | <u>2024</u> | <u>2025</u> | <u>2026</u> | <u>2027</u> | <u>Overall</u> | |
|----------------|------------|---------------|---------------|-----------------|-------------|---------------|-----------------|--|
| Internal Labor | = | | = | = | = | = | = | |
| Materials | = | = | = | = | = | = | = | |
| Subcontractor | = | = | = | = | = | = | = | |
| Miscellaneous | 325,000.00 | 170,000.00 | 635,000.00 | 1,270,000.00 | = | 670,000.00 | 3,070,000.00 | |
| (CIAC) Reim | | | | _ | | | | |
| Subtotal: | 325,000.00 | \$ 170,000.00 | \$ 635,000.00 | \$ 1,270,000.00 | \$ - | \$ 670,000.00 | \$ 3,070,000.00 | |
| Impact Fee % | 0% | 0% | 0% | 0% | 0% | 0% | 0% | |
| Net Amount: | 325,000.00 | \$ 170,000.00 | \$ 635,000.00 | \$ 1,270,000.00 | \$ - | \$ 670,000.00 | \$ 3,070,000.00 | |

Approved: 12/15/2021 Page 73 of 75



Metering

1) 2022 Metering Installs

Approved: 12/15/2021 Page 74 of 75

Project Analysis Form

Project Name: 2022 Capital Improvements - Metering

Project Driver: Growth

Priority Level: Medium

Purpose & Necessity:

The following collective list of minor capital assets are various metering components that will be purchased over 2021 for installation:

| Generation 4 CL 200 Meters \$90,600 | Current Transformers Bar Type 100:5 \$2,300 |
|-------------------------------------|--|
| CL320 Meters\$4,600 | Current Transformers Bar Type 200:5 \$2,500 |
| 3S 120 Volt Meters\$300 | Current Transformers Bar Type 300:5 \$800 |
| 3S 240 Volt Meters \$300 | Current Transformers Window Type 200:5 \$100 |
| 16S Meters\$5,800 | Current Transformers Window Type 300:5 \$500 |
| 9S Meters\$3,900 | Current Transformers Window Type 400:5 \$500 |
| Test Switches Single Phase \$200 | Current Transformers Window Type 600:5 \$400 |
| Test Switches Three Phase \$1,600 | |

Risk Assessment:

New meters are typically required to meet the new connections demand. The only risk that is involved in the purchase of these metering components is the cash flow risk as these items are purchased and stored in advance of the collection of the impact fee from the customer.

Cash Flow Schedule:

| | <u>2022</u> | <u>20</u> | <u>23</u> | 2 | <u>024</u> | 2 | 025 | 20 | 026 | 20 | <u>027</u> | <u>Overall</u> |
|----------------|-------------|-----------|-----------|----|------------|----|-----|----|-----|----|------------|-----------------|
| Internal Labor | - | | | | - | | - | | - | | - | - |
| Materials | 114,400.00 | | - | | - | | - | | - | | - | 114,400.00 |
| Subcontractor | - | | - | | - | | - | | - | | - | - |
| Miscellaneous | - | | - | | - | | - | | - | | - | - |
| (CIAC) Reim | (96,096.00) | | - | | - | | | | | | - | (96,096.00) |
| Subtotal: \$ | 18,304.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 18,304.00 |
| Impact Fee % | 0% | | | | | | | | | | | |
| Net Amount: | 18,304.00 | \$ | - | \$ | - | \$ | - | \$ | - | \$ | - | \$ 18,304.00 |

Approved: 12/15/2021 Page 75 of 75